

# Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

## Part A

Permit Number	<b>EPR/LP3030XA</b>
Name of operator	<b>Viridor Trident Park Limited</b>
Location of Facility	Glass Avenue, Cardiff. CF24 5EN
Time and date of the detection	20 December 2021 15:00H

### (a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

#### To be notified within 24 hours of detection

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

### (b) Notification requirements for the breach of a limit

#### To be notified within 24 hours of detection unless otherwise specified below

Emission point reference/ source	CEMS analyser LINE 1
Parameter(s)	HCl
Limit	60 mg/m <sup>3</sup>
Measured value and uncertainty	72.47 mg/m <sup>3</sup>
Date and time of monitoring	20 December 2021 from 14:30 to 14:59H
Measures taken, or intended to be taken, to stop the emission	Upon detection of HCl spike the boiler load was reduced and the Stand-by reagent dosing line was started to supplement the Duty reagent dosing line. This intervention was successful in returning subsequent half hourly averages to normal levels.

#### Time periods for notification following detection of a breach of a limit

Parameter	Notification period

### (c) Notification requirements for the detection of any significant adverse environmental effect

#### To be notified within 24 hours of detection

Description of where the effect on the environment was detected	
Substances(s) detected	



<b>Name*</b>	[REDACTED]
<b>Post</b>	EHS Manager
<b>Signature</b>	[REDACTED]
<b>Date</b>	21_12_2021

\* authorised to sign on behalf of **Viridor Trident Park Limited**