



2. Declaration of Conformity

SMALL SCALE WASTEWATER TREATMENT




EN 12566-3

DECLARATION OF CONFORMITY

Manufacturer

Name Viltra
Address 56 Damolly Road
 Newry, Co. Down
 BT34 1QR

Represented by the signature, declares that the following product:





Oxcrete 97.5%

Corresponds to all requirements in annex ZA according to the European standard EN 12566-3:2005+A1
 “Small wastewater treatment systems for up to 50 PT - Part 3: Packaged and/or site assembled domestic wastewater treatment plants”
 According to PIA SR66-1611-1126

<p>Product description</p> <p>Nominal organic daily load</p> <p>Daily hydraulic flow</p> <p>Watertightness (water test)</p> <p>Structural behaviour</p> <p>Treatment efficiency (nominal sequences)</p> <p>Electrical consumption</p>	<p>Sewage treatment system</p> <p>0.3kg/day</p> <p>0.9m³/day</p> <p>Pass</p> <p>Pass</p> <p>COD 93.2%</p> <p>BOD₅ 97.5%</p> <p>TSS 97.0%</p> <p>0.59kWh/d</p>
---	--

Approved body

PIA - Prüfinstitut für Abwassertechnik GmbH
 (PIA GmbH)
 Hergenrather Weg 30
 52074 Aachen, Germany

Notified Body No. 1799
 Certified according to ISO 9001:2015