

Permit Reference Number: BL3986ID

Operator: Aberthaw Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Air 11 / 19/07/2016

**Six-monthly Reporting of Particulate Emissions to Air from Emission Points A4, A5, A6 & A11
for the period from 01/07/24 to 31/12/24**

Emission Point	Parameter	Emission Limit Value (mg/Nm ³)	Result (mg/Nm ³) 1 st Six months	Result (mg/Nm ³) 2 nd Six months	Test Method	Sample Date & Times	Uncertainty
A4	Particulate Matter	10	2.46	3.79	BS EN 13284-1	25.03.2024 12:21 – 13:23 25.09.2024 08:33 – 10:57	1.84 0.21
A5	Particulate Matter	10	-		BS EN 13284-1	-	-
A6	Particulate Matter	10	-		BS EN 13284-1	-	-
A11	Particulate Matter	10	-		BS EN 13284-1	-	-

Signed: ██████████ Date 17.01.2025
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)