



Tecnidro S.r.l. Via
G. Gastaldi 26/F
16163 Genova

Test certificate



CLIENTE CUSTOMER	WD METERS LTD	
RIF. ORDINE ORDER N°	PO-0210	DEL DATE 06/03/2018
BOLLA N° DOCUMENT OF TRANSPORT		DEL DATE (SALE) 19.11.2018
ARTICOLO ITEM	TW-P WATER METER DN 150	

	DN	Qn	Flow rate	Measured V	Dial Volume	Difference	Error
Serial n°	[mm]	[m³/h]	[m³/h]	[l]	[l]	[l]	[%]
R1615475	150	150	162,3	2896,5	2851,4	-45,1	-1,60%

ESITO:	X CONFORME	NON CONFORME
Result	In conformity	Not in conformity
Limite di accettabilità intervallo Q_n / Accuracy tolerance Q_n : $\Delta = \pm 2\%$		
Limite di accettabilità intervallo Q_t / Accuracy tolerance Q_t : $\Delta = \pm 5\%$		
Limite di accettabilità intervallo Q_{min} / Accuracy tolerance Q_{min} : $\Delta = \pm 5\%$		

Procedura di controllo ed accettazione	Procedura Tecnidro n° 05. rev.5 dtd. 03/04/2017
	Istruzione di controllo Tecnidro n° rev.
	Altro

FIRMA DEL COLLAUDATORE
OPERATOR SIGNATURE

TECNIDRO S.r.l.
Via G. Gastaldi 26/F
16163 Genova

Data 13/04/18	
---------------	--