

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

No. 189
(Amended)

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES												
9th March, 1982.	Welsh Water Authority Llansannan Sewage Treatment Works.												
USE OF NEW OR ALTERED OUTLET	DISCHARGE OF TRADE OR SEWAGE EFFLUENT												
<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) PRECISE LOCATION OF OUTLET</p> <p style="padding-left: 40px;">Discharge to the Afon Aled at NGR SH.9371 6601.</p> <p>(ii) CONSTRUCTION OF OUTLET <small>(OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE)</small></p> <p>(iii) USE OF OUTLET</p> <p style="padding-left: 40px;">Discharge of treated sewage effluent only.</p> <p>(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES</p>	<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) NATURE AND COMPOSITION OF DISCHARGE</p> <p>1. The discharge shall consist only of treated sewage effluent from the above works.</p> <p>2. The quality and quantity of effluent shall not exceed the following <u>maximum</u> values:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;"><u>Determinand.</u></th> <th style="text-align: right;"><u>Value/Unit</u></th> </tr> </thead> <tbody> <tr> <td>Biochemical Oxygen Demand (+AMU) over 5 days at 20°C.</td> <td style="text-align: right;">50 mg/l.</td> </tr> <tr> <td>Suspended Solids dried at 105°C.</td> <td style="text-align: right;">60 mg/l.</td> </tr> <tr> <td>Rate of discharge.</td> <td style="text-align: right;">2.3 l/sec.</td> </tr> <tr> <td>Volume during any period of 24 consecutive hours.</td> <td style="text-align: right;">196.5 cu.m.</td> </tr> <tr> <td>Volume discharged under 'dry weather conditions' during any period of 24 consecutive hours.</td> <td style="text-align: right;">65.5 cu.m.</td> </tr> </tbody> </table> <p>(ii) TEMPERATURE OF DISCHARGE</p> <p>(iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES</p> <p>* (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES</p> <p>Adequate facilities shall be provided for the taking of samples of the effluent at the outlet from humus tank.</p> <p>(v) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER 5.5(2) OF 1961 ACT</p> <p style="text-align: center;">9th March, 1984.</p>	<u>Determinand.</u>	<u>Value/Unit</u>	Biochemical Oxygen Demand (+AMU) over 5 days at 20°C.	50 mg/l.	Suspended Solids dried at 105°C.	60 mg/l.	Rate of discharge.	2.3 l/sec.	Volume during any period of 24 consecutive hours.	196.5 cu.m.	Volume discharged under 'dry weather conditions' during any period of 24 consecutive hours.	65.5 cu.m.
<u>Determinand.</u>	<u>Value/Unit</u>												
Biochemical Oxygen Demand (+AMU) over 5 days at 20°C.	50 mg/l.												
Suspended Solids dried at 105°C.	60 mg/l.												
Rate of discharge.	2.3 l/sec.												
Volume during any period of 24 consecutive hours.	196.5 cu.m.												
Volume discharged under 'dry weather conditions' during any period of 24 consecutive hours.	65.5 cu.m.												
REMARKS-	REMARKS-												