

# Notice of transfer with introductory note

The Environmental Permitting (England & Wales) Regulations 2010

---

Dŵr Cymru Cyfyngedig

Rhoose Point Sewage Pumping Station  
Bryn-Y-Gloyn  
Rhoose Point  
Vale of Glamorgan  
CF62 3LD

Transfer application number  
AN029900101/T002

Permit number  
AN029900101

# Rhose Point Sewage Pumping Station

## Permit number AN029900101

### Introductory note

#### This introductory note does not form a part of the notice

The following notice gives notice of the transfer of an environmental permit to a new operator (the transferee).

Permit transferred in full to Dŵr Cymru Cyfyngedig.

The status log of a permit sets out the permitting history, including any changes to the permit reference number.

<b>Status log of the permit</b>		
<b>Description</b>	<b>Date</b>	<b>Comments</b>
Application AN029900101/T002 (full transfer of permit AN029900101)	Duly made 18/03/2015	Application to transfer the permit in full to Dŵr Cymru Cyfyngedig.
Transfer determined AN029900101	27/03/2015	Full transfer of permit complete.

End of introductory note

## Notice of transfer

The Environmental Permitting (England and Wales) Regulations 2010

The Natural Resources Body for Wales (“Natural Resources Wales”) in exercise of its powers under regulation 21 of the Environmental Permitting (England and Wales) Regulations 2010 transfers

**permit number**

**AN029900101**

**to**

**Dŵr Cymru Cyfyngedig** (“the operator”)

whose registered office is

**Pentwyn Road**

**Nelson**

**Treharris**

**CF46 6LY**

company registration number 02366777

to operate a regulated facility at

**Rhose Point Sewage Pumping Station**

**Bryn-Y-Gloyn**

**Rhose Point**

**Vale of Glamorgan**

**CF62 3LD**

**from Cofton Limited**

This notice shall take effect from 17/04/2015.

Name

Date

**Caroline Drayton**

**27/03/2015**

Authorised on behalf of Natural Resources Wales

Ein Cyf/Our ref: 1/FD/Ab/IJM/T30  
Eich Cyf/Your ref:

Dyddiad/Date: 15 May 2000



ASiantaeth YR  
AMGYLCHEDD CYMRU  
ENVIRONMENT  
AGENCY WALES

Ove Arup and Partners  
4 Pierhead Street  
Capital Waterside  
Cardiff  
CF10 4QP

FAO: Andrew McElwee

Dear Sir,

**COFTON LIMITED - RHOOSE POINT**

ARUP CARDIFF			
REC'D	17 MAY 2000		
JOB No.	57155	FILE No.	6-53
PROJ. MAN.	AS	PROJ. DIR	
ACTION RESPONSE	ANCE	GRP. LTR.	

I refer to your application for Formal Land Drainage Consent dated 19 April 2000 for the construction of three outfalls at the above.

Under the terms of the Water Resources Act 1991 and the Land Drainage Byelaws, the prior written consent of The Agency is required for any proposed works or structures in, under, over or within 7 metres of the landward toe of any floodbank or wall, or where there is no such bank or wall, within 7 metres top of the bank of a main river.

Further, the prior written consent of The Agency, is required, under the terms of the Land Drainage Act 1991, if any works include the erection of or alteration to a culvert, dam weir or similar construction is any watercourse.

Therefore, as your proposal to construct the said outfalls do not affect any main river watercourses, Formal Land Drainage Consent is not required in this instance.

I have arranged for your application fee to be refunded and if you have any further queries regarding the above, please do not hesitate to contact me.

Yours faithfully,



**IAN JOHN MARTIN**  
Flood Defence Officer

Asiantaeth yr Amgylchedd Cymru  
Ty Abacus, Parc Busnes Llancirwg, Llancirwg, Caerdydd, CF3 0LT  
Ffon: 029 20770088 Ffacs: 029 20798555

Environment Agency Wales  
Abacus House, St Mellons Business Park, St Mellons, Cardiff, CF3 0LT  
Tel: 029 20770088 Fax: 029 20798555



ASIANTAETH YR  
AMGYLCHEDD CYMRU  
ENVIRONMENT  
AGENCY WALES

Eich cyf/Your ref.

Ein cyf/Our ref. AN0299001/CMc

Dyddiad/Date: 1 September, 2000

Mr A McElwee  
Ove Arup & Partners  
4 Pierhead Street  
Capital Waterside  
Cardiff  
CF10 4QP

ARUP CARDIFF			
REC'D	-4 SEP 2000		
JOB No.	59185	FILE No.	6-53
PROJ. MAN.	DS	INTL	PROJ. DIR.
ACTION	AT	GRP. LDR.	
REMARKS			

Dear Mr McElwee,

**RE: WATER RESOURCES ACT 1991, SCHEDULE 10 (AS AMENDED BY THE ENVIRONMENT ACT 1995) APPLICATION FOR CONSENT TO DISCHARGE AT ST 0680 6575 BY COFTON LTD, FIRSWOOD ROAD, GARRETT'S GREEN BIRMINGHAM FROM PREMISES AT A DEVELOPMENT AT RHOOSE POINT. APPLICATION NO. AN0299001.**

Further to your application the Agency has decided that consent should be given subject to conditions. I enclose the Agency's formal consent to discharge Sewage Effluent in an emergency from a Sewage Pumping Station.

Under the present Scheme of Charges for Discharges to Controlled Waters an annual charge will be made for all consents to discharge, except where the discharge is of sewage effluent of five cubic metres or less per day. The charge is based on information derived from the conditions attached to the consent to discharge, as outlined in the enclosed leaflet.

If you consider that the conditions imposed by the consent are unreasonable you have a right of appeal to the National Assembly for Wales at Cathays Park, Cardiff CF10 3NQ.

Notice of an appeal must be given in writing within three months of this notification and must be accompanied by a statement of the grounds of appeal.

If granted, a consent under Schedule 10 of the Act, covers water quality considerations only. It does not alter the need to obtain any other consents or approvals which might be required in connection with your proposal under other legislation. For example it does not give any right or permission to discharge where land is not owned by the applicant.

Asiantaeth yr Amgylchedd Cymru  
Plas yr Afon, Parc Busnes Llancirwg, Llancirwg, Caerdydd CF3 0EY  
Cyfeiriad DX 121375, Ffon 029 20770088, Ffacs 029 20798555, GTN 7-26 X 1000

Environment Agency Wales  
Rivers House, St. Mellons Business Park, St. Mellons, Cardiff CF3 0EY  
DX Address 121375, Tel 029 20770088, Fax 029 20798555, GTN 7-26 X 1000



Please take careful note that if the holder of the consent changes, you must inform the Agency **IN WRITING** as soon as possible of the name of the new holder. This is to ensure that the rights and charges associated with the Consent are transferred to the new holder. A Certificate of Holder notice will be sent to you shortly which is designed for this purpose, and should be kept safely with the Consent until required.

If you have any queries regarding the enforcement of this consent, please do not hesitate to contact Phil Burgess, Team Leader Environment Protection, on 029 20 770088 quoting extension 2149.

Yours sincerely,

  
**MARTIN MILLS**  
**Environment Planning Manager**



Enc.

CONSENT NO.	AN0299001
-------------	-----------



ASiantaeth yr  
AMGYLCHEDD CYMRU  
ENVIRONMENT  
AGENCY WALES

**WATER RESOURCES ACT 1991**

**SECTION 88 - SCHEDULE 10**

**(AS AMENDED BY THE ENVIRONMENT ACT 1995)**

**CONSENT TO DISCHARGE**

**TO:** Development Manager  
Cofton Ltd  
Firswood Road  
Garretts Green  
Birmingham B33 0ST

The **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY CONSENTS** to the making of a discharge **OF SEWAGE EFFLUENT**, as follows:

Sewage in an Emergency

**FROM:** A Sewage Pumping Station

**AT:** Development at Rhoose Point.

**TO:** a lake

**SUBJECT TO** the conditions set out in the following schedule:

Sewage in an Emergency      Schedule No. AN029900101

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources act 1991, no notice shall be served by the Agency, altering this consent, without the agreement in writing of the Consent Holder, during a period of 4 years from the date this consent takes effect.

This consent is issued and takes effect on the 31<sup>st</sup> day of August 2000

Signed .....  .....  
Area Environment Planning Manager

Asiantaeth yr Amgylchedd

Plas yr Afon, Parc Busnes Llancirwg, Llancirwg, Caerdydd CF3 0EY. Ffôn 029 20770088, Ffacs 029 20798555

Environment Agency

Rivers House, St. Mellons Business Park, St. Mellons, Cardiff CF3 0EY. Tel 029 20770088, Fax 029 20798555



ASiantaeth Yr  
Amgylchedd Cymru  
ENVIRONMENT  
AGENCY WALES

CONSENT NO	AN0299001
SCHEDULE NO	AN029900101
DATE ISSUED	31/8/00

### CONDITIONS OF CONSENT TO DISCHARGE

#### Sewage in an Emergency ("the Discharge")

**FROM:** a Sewage Pumping Station, at a Development at Rhoose Point.

#### NATURE

1. The Discharge shall consist solely of sewage in an emergency.
2. The Discharge shall only occur when the sewage pumping station is inoperative as a result of one or more of the following:
  - (i) electrical power failure not due to the act or default of the Consent Holder, its agents, representatives, officers, employees or servants;
  - (ii) mechanical breakdown of duty and standby pumps;
  - (iii) rising main failure;
  - (iv) blockage of the downstream sewer not due to the act or default of the Consent Holder, its agents, representatives, officers, employees or servants;

and it is not reasonably practicable to dispose of the sewage otherwise. There shall be no undue delay on the part of the Consent Holder in remedying any such failure or breakdown.

#### LOCATION

3. The Discharge shall be made in the manner and at the place specified as:
  - (a) discharging via a 150 millimetre diameter pipe;
  - (b) discharging to a lake;
  - (c) at National Grid Reference ST 0680 6575;
  - (d) shown marked 'Consent Point' on Plan AN0299001 attached as Annex 1.



ASiantaeth yr  
Amgylchedd Cymru  
Environment  
Agency Wales

CONSENT NO	AN0299001
SCHEDULE NO	AN029900101

### SAMPLE POINT

4. The outlet to the lake shall be constructed and maintained so that a representative sample of the Discharge may be obtained at National Grid Reference ST 0680 6575, as shown marked 'Consent Point' on Plan AN0299001.

### VOLUME

5. Storage capacity, equivalent to a total of at least 6 hours of the dry weather flow in the sewer immediately upstream of the pumping station, shall be provided in the pumping station and/or the upstream sewerage system, above the wet well design top water level.

### COMPOSITION

6. (a) The Discharge shall have passed, without prior comminution or maceration, through a screening device having apertures no greater than 6 millimetres in one dimension.
- (b) The screening device shall be maintained in an efficient operational condition.
- (c) All screenings must be removed and disposed of in a manner such as to prevent entry to the discharge.

### TELEMETRY

7. (a) A 24 hour response telemetry alarm system shall be provided and maintained to give notification of failure or breakdown of the pumping station.
- (b) The Consent Holder shall take all reasonable remedial measures to return the pumping station to normal operation, as soon as practicable after warning of failure or breakdown of the pumping station.
- (c) The consent holder shall notify the Agency, as soon as practicable, when there is potential for operation of the emergency overflow in the event of failure or breakdown of the pumping station.

CONSENT NO	AN0299001
SCHEDULE NO	AN029900101



ASiantaeth yr  
Amgylchedd Cymru  
Environment  
Agency Wales

#### OTHER

8. (a) The duty pump(s) shall be maintained in good working order, and at least one stand-by pump shall be provided and maintained.
  - (b) Stand-by pump(s) shall as soon as practicable activate should the duty pump(s) become inoperative for reasons other than power failure. The pumping station shall be maintained so that the pump shall reactivate as soon as is practicable after the power is restored after the interruption to the supply.
9. Facilities shall be provided so that a mobile stand-by generator may readily be installed at the pumping station in the event of electrical failure and the consent holder shall install and operate such a generator as soon as is practicable after an electrical failure.
  10. A tanker access facility at an appropriate location shall be provided and maintained to enable removal of sewage by tanker when necessary.



LOCATION OF PROPOSED FOUL PUMPING STATION TO BE ADOPTED BY WELSH WATER WITH EMERGENCY OVERFLOW TO LAKE AND 6HRS STORAGE

2 NO. FREE OUTFALLS FROM THE EAST AND WEST LOOPS TO BE THE LIMITS OF THE ADOPTION BY WELSH WATER

CONSENT POINT

RECEIVING LAKE WHICH CURRENTLY DISCHARGES THROUGH THE CLIFF TO THE FORESHORE AND WILL BE MAINTAINED BY COFTON

ASIANI TAETH YR AMGYLCHEDD	
ENVIRONMENT AGENCY	
CONSENT PLAN NUMBER	AN10249001
AUTHORISED SIGNATURE	<i>Shardyl Jones</i>

