

enfinium Parc Adfer Operations Ltd - Carbon Capture Facility  
**Carbon Dioxide Venting Strategy**

---

## 1 Introduction

enfinium Parc Adfer Operations Ltd (enfinium) is applying for a variation to the EP (Ref: EPR/AB3092CV) for the Parc Adfer Energy Recovery Facility (ERF) to incorporate the proposed carbon capture facility (CC facility).

During normal operation the captured CO<sub>2</sub> will be exported from the site via pipeline for offshore sequestration. However, there will be operational scenarios where the captured CO<sub>2</sub> cannot be exported. In such scenarios the captured CO<sub>2</sub> will be vented to atmosphere. It is anticipated that enfinium will be required to provide Natural Resources Wales (NRW) with a Venting Management Plan as a pre-operational condition. Full details of the CO<sub>2</sub> venting process and venting scenarios to inform the Venting Management Plan will be developed during detailed design of the CC facility. This document has been prepared to outline the scenarios under which CO<sub>2</sub> venting may or will occur and the proposed design and management techniques for CO<sub>2</sub> venting and identify any potential for significant environmental impacts as a result of CO<sub>2</sub> venting.

## 2 CO<sub>2</sub> vent design

The proposed design of the CC facility includes a CO<sub>2</sub> vent header system. In all scenarios which will require venting of CO<sub>2</sub>, all CO<sub>2</sub> within the CC facility will be directed to the header and then to the CO<sub>2</sub> vent stack. It is proposed that the CO<sub>2</sub> vent release point will be at the top of the 85 m stack for the CC facility. High-pressure CO<sub>2</sub> vent pipework may require heating to compensate for the temperature drop on expansion as CO<sub>2</sub> pressure reduces. The requirement for heating will be determined during detailed design.

## 3 CO<sub>2</sub> venting scenarios

Initially, it has been identified that there are five scenarios that would require CO<sub>2</sub> venting:

1. Venting of out of specification CO<sub>2</sub>, i.e. the CO<sub>2</sub> does not meet the specification of the pipeline and storage network;
2. Venting of CO<sub>2</sub> due to operational upset of the CC facility;
3. Depressurisation of equipment to perform maintenance or inspections;
4. Plant commissioning; and
5. Start-up and shutdown of the CC facility.

The Venting Management Plan will include details of CO<sub>2</sub> process conditions, release rates, total mass of CO<sub>2</sub> to be vented, and venting duration for all of the above scenarios. At this stage it is

anticipated that the maximum potential duration of any of the venting scenarios will be approximately six hours, which would occur during start-up and shut-down of the CC facility.

## 4 Potential impacts

It is proposed that the CO<sub>2</sub> vent will be at the top of the stack for the CC facility, which is the same height as the existing ERF stack. At present, all CO<sub>2</sub> produced by the combustion of waste in the ERF is released in the flue gas from the ERF. For the CC facility design it is proposed that CO<sub>2</sub> would be vented from the CC facility stack so the plumes will combine. As such, during CO<sub>2</sub> venting the plume will be very similar to that during normal operation of the ERF, except at a lower release temperature. The design temperature for treated flue gas from the CC facility is 80°C, although this would likely be reduced during CO<sub>2</sub> venting, depending on the temperature of the CO<sub>2</sub> release.

There is the potential for CO<sub>2</sub> to be vented when there is no treated flue gas being released from the CC facility stack, for example during depressurisation of equipment to perform maintenance or inspections. In such scenarios, as CO<sub>2</sub> capture will not be ongoing, the total mass of CO<sub>2</sub> vented will be limited to the capacity of the CC facility pipework. In such scenarios the short duration and minimal mass of the release would mean that there is no potential for a significant impact when the CO<sub>2</sub> is released from a height of 85 m.

As such, it is anticipated that there is no risk of a significant impact due to CO<sub>2</sub> venting. This will be confirmed as part of the Venting Management Plan prior to operation of the CC facility.

FICHTNER Consulting Engineers Limited



Stuart Nock  
Senior Consultant



James Sturman  
Principal Consultant