

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	BW9999IG/V010
Name of operator	Kronospan Limited
Location of Facility	Holyhead Road, Chirk, Wrexham, LL14 5NT.
Time and date of the detection	31/07/2025

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified within 24 hours of detection	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	


(b) Notification requirements for the breach of a permit condition	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	A26 K7 Biomass Boiler
Parameter(s)	NOx; CO
Limit	250mg/m³; 150mg/m³
Measured value and uncertainty	362.3mg/m³ (±45.5); 352mg/m³ (±72.8)
Date and time of monitoring	19/05/2025 10:06 - 11:50
Measures taken, or intended to be taken, to stop the emission	The emissions are vented to atmosphere via the MDF Cyclones following heat recovery within the MDF Dryer. At the point of emission, all limits are met for NOx and CO.

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	Please also refer to previous correspondence relating to K7 BAT review – sent 30/05/24.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Works in relation to improvements on K7 are detailed in IC Conditions 56 to 61 of V011.	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission		
The dates of any unauthorised emissions from the facility in the preceding 24 months.	13/11/2022	11/05/2023
	01/02/2023	03/07/2023
	13/04/2023	07/08/2023
	24/04/2023	16/09/2023
	25/04/2023	18/09/2023
	30/04/2023	02/01/2024
	02/05/2024	02/05/2024
	28/06/2024	16/07/2024

Name*	Victoria Smith
Post	Environment Officer
Signature	
Date	31/07/2025

* authorised to sign on behalf of the Operator