

Permit Number: PP3238LX

Operator: Bakelite Synthetics UK Limited

Facility: Barry Thermosets Plant

Form Number: Water1 / 13/02/2023

Reporting of emissions to water (other than to sewer) and land for the period from 29/03/2024 to 27/06/2024

Emission Point	Substance / Parameter	Emission		Reference Period	Result ^[1]	Average result ^[6]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value							
W1	Maximum volume of effluent discharged under dry conditions determined by no significant rainfall over the previous 48 hours on the Barry site.	6800 m ³ /day	Instantaneous		2409	409		04/04/2024 11/04/2024 18/04/2024 25/04/2024 02/05/2024 09/05/2024 16/05/2024 23/05/2024 30/05/2024 06/06/2024 13/06/2024 20/06/2024 27/06/2024	
	Maximum volume of effluent discharged	15,900 m ³ /day	Instantaneous		2409	409		As above	
	Flow	0.19 m ³ /s	Instantaneous		0.028	0.0047		As above	
	Monohydric phenol	10 mg/l	24-hour flow proportional sample		4.19	1.0	BS6068-2.12 1990 ISO6439:1990	As above	0.813
	Total suspended solids	150 mg/l	24-hour flow proportional sample		132	36.3	BS EN 872 2005 /BS6068- 2.54 2005	As above	18.8
	Chemical oxygen demand	1000 mg/l	24-hour flow proportional sample		405	130	BS ISO 15705-2002/BS6068-2.80 2002	As above	58.2
	Methanol	50 mg/l	24-hour flow proportional sample		0	0	BS EN ISO 15680 2003	As above	0
	Free formaldehyde	10 mg/l	24-hour flow proportional sample		0.66	0.1	BS 2942 App D	As above	0.108
	Styrene ^[5]	No limit set	24-hour flow proportional sample		n/a	n/a			
	pH	Minimum 6, maximum 9	Instantaneous		8.1	7.5	BS6068-2.50	As above	0.238

Emission Point	Substance / Parameter	Emission		Result ^[1]	Average result ^[6]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value	Reference Period					
	Monohydric phenol	10950 kg/year	Annual mass release	n/a	n/a			
	Methanol	43800 kg/year	Annual mass release	n/a	n/a			
	Free formaldehyde	10950 kg/year	Annual mass release	n/a	n/a			
E1	Total suspended solids	No limit set	24-hour flow proportional sample	68.4	26.5	BS EN 872 2005 /BS6068- 2.54 2005	As above	13.4
	Free formaldehyde	No limit set	24-hour flow proportional sample	1.38	0.3	BS 2942 App D	As above	0.260
	Monohydric phenol	No limit set	24-hour flow proportional sample	11.68	1.9	BS6068-2.12 1990 ISO6439:1990	As above	1.82
	Methanol	No limit set	24-hour flow proportional sample	0	0	BS EN ISO 15680 2003	As above	0
	Chemical oxygen demand	No limit set	24-hour flow proportional sample	461	163	BS ISO 15705-2002/BS6068-2.80 2002	As above	68.7

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[5] Monitoring of styrene required when styrene is in use at the installation

[6] An average of the samples taken over the reporting period (every 3 months)

Signed
(Authorised to sign as representative of Operator)

Date.....5th July... 2024.....