

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



ENVIRONMENT
AGENCY

Part A

To: HAVEN LEISURE LTD

THE MANAGER

CARMARTHEN BAY HOLIDAY PARK

KIDWELLY SA17 5HQ

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BE0017501

Nature of Discharge(s): TRADE EFF/TREATED EFF/CONTINUOUS
at SW.POOL & BOILER PLANT CARAVAN PARK FERRYSIDE

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor. To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed:

Dated:


Name (block capitals):

Position:

WRS05

Copy completed when signing





25/6/91

Mr. A. D. Brown

General Manager

Warner Holiday Park

Kidwelly

Deypor

SA17 5HP.

New owners



C175

Scheme No. C.175

SOUTH WEST WALES RIVER AUTHORITY
RIVERS (PREVENTION OF POLLUTION) ACTS, 1951-1961
Consent to discharge of effluent

The South West Wales River Authority pursuant to the provisions of the above mentioned Acts, hereby consent to the construction of an outlet and to the discharge of effluent therefrom upon the following conditions:—

1. NAME AND ADDRESS OF PERSON to whom consent is given
**St. Donats Holiday Estates Ltd.,
St. Ithelwells Cerrwyn Park, Yerrylide, Carmarthen,
Swimming Pool and Jetties Plant, St. Ithelwells
Cerrwyn Park, Yerrylide, Carmarthen.**

2. PREMISES to which consent relates
3. OUTLET
(a) Location—situated on right bank of the unnamed tributary of the River Cerrwyn at Yerrylide.
Map reference **O.S. 24 SF 30** Grid reference **366 074**
(b) Construction—**4** diameter **C.I. or U.P.** Pipe
(c) Use—restricted to **Storage/Septic/Trade/Farm** Effluent produced at the above mentioned premises.

4. DISCHARGE
(a) Name **Trade effluent**
(b) Volume or rate of discharge **200 gallons per min. for five mins every three days.**
Maximum rate of discharge **1,250 gallons per day.**
(c) Temperature not to exceed **21** °C.
(d) Composition:—
(i) pH value not less than **6.0** or more than **8.5**
(ii) ~~Sulphide ions not more than~~
(iii) ~~Disinfectant residue not more than~~
(iv) ~~Free chlorine not more than~~
(v) ~~Free ammonia not more than~~
(vi) ~~Free iron not more than~~
(vii) ~~Free copper not more than~~
(viii) ~~Free lead not more than~~
(ix) ~~Free zinc not more than~~
(x) ~~Free cadmium not more than~~
(xi) ~~Free mercury not more than~~
(xii) ~~Free manganous ions not more than~~
(xiii) ~~Free nitrate ions not more than~~
(xiv) ~~Free nitrite ions not more than~~
(xv) ~~Free fluoride ions not more than~~
(xvi) ~~Free cyanide ions not more than~~
(xvii) ~~Free boron not more than~~
(xviii) ~~Free selenium not more than~~
(xix) ~~Free tellurium not more than~~
(xx) ~~Free antimony not more than~~
(xxi) ~~Free arsenic not more than~~
(xxii) ~~Free barium not more than~~
(xxiii) ~~Free bismuth not more than~~
(xxiv) ~~Free calcium not more than~~
(xxv) ~~Free cobalt not more than~~
(xxvi) ~~Free chromium not more than~~
(xxvii) ~~Free manganese not more than~~
(xxviii) ~~Free nickel not more than~~
(xxix) ~~Free potassium not more than~~
(xxx) ~~Free sodium not more than~~
(xxxi) ~~Free strontium not more than~~
(xxxii) ~~Free vanadium not more than~~
(xxxiii) ~~Free molybdenum not more than~~
(xxxiv) ~~Free tungsten not more than~~
(xxxv) ~~Free uranium not more than~~

5. PERIOD OF CONSENT
(e) Sampling point to be located at **wastewater discharge and pump in filterhouse.**
The terms of this consent will not without the consent in writing of the person to whom this consent is given be altered before the expiration of the period ending with the **30th** day of **September** 19 **75**

Dated this **20th** day of **September** 19 **75**
Penyfa House,
19, Penyfa Lane,
Furnace,
LIANELLI,
Carmarthen.
SA15 4EL
Clerk and Chief Executive Officer.
RECORDED DELIVERY No. **3 063996**

