

Compliance Assessment Report CAR_NRW0049198

Licence being assessed: WA/067/0001/021.
For: Dolhendre Caraven Park, held by DHJC Limited.
At: Dolhendre Caravan Park, Llanuwchllyn, Bala, Gwynedd, LL23 7TD.

Type of assessment: Site Inspection, Reason: Routine.
On 31/07/2025, between 11:00 and 11:30.
Parts of licence assessed: All

NRW Lead Officer: Laura Jones, accompanied by Sioned Jones.
Report sent to: DHJC Limited, Permit Holder, on 22/08/2025.

1. Summary of our findings (full details in section 4)

Part of licenced activity assessed (criteria)	Assessment result	Licence condition
WR-A1 - Water Abstraction - Abstraction specified by licence - Source of supply	Assessed (A)	
WR-A2 - Water Abstraction - Abstraction specified by licence - Points of abstraction	Assessed (A)	
WR-A3 - Water Abstraction - Abstraction specified by licence - Means of abstraction	Assessed (A)	
WR-A4 - Water Abstraction - Abstraction specified by licence - Purposes of abstraction	Assessed (A)	
WR-A5 - Water Abstraction - Abstraction specified by licence - Period of abstraction	Assessed (A)	
WR-A6 - Water Abstraction - Abstraction specified by licence - Quantities	Assessed (A)	
WR-B2 - Water Abstraction - Abstraction measurement and records - Recording	Assessed (A)	
WR-B3 - Water Abstraction - Abstraction measurement and records - Reporting	Assessed (A)	

Result types are explained in more detail in the 'Important Information' section below.

2. What action is required?

No action required.

3. What will happen next?

Any non-compliance we have identified and recorded on this form is an offence. It can result in criminal prosecution or civil sanctions being imposed depending on the circumstances of the offence.

At this time, we do not intend to take any further action.

This statement does not stop us from taking additional enforcement action if further relevant information comes to light or offences continue.

4. Details of our assessment

The abstraction licence to abstract water from inland water (stream) known as Afon Lliw near Dolhendre Caravan Park, Llanuwchllyn, Bala, Gwynedd was inspected by Laura Jones from the Conwy Environment Management team and Sioned Jones from the Dwyfor and Meirionydd Environment Management team on the 31st July 2025.

1. Source of Supply

Inland water (stream) known as Afon Lliw near Dolhendre Caravan Park, Llanuwchllyn, Bala, Gwynedd

No issues were identified

2. Point of Abstraction

At National Grid Reference SH 84281 31596

No issues were identified

3. Means of Abstraction

Intake works and a gravity feed pipe of an internal diameter not exceeding 1000 millimetres

No measurements of this pipe took place during the visit

4. Purpose of Abstraction

Power production

No issues were identified

5. Period of Abstraction

All year

No issues were identified

6. Maximum Quantities of Water to be Abstracted

30,240 cubic meters per day

11,037,600 cubic meters per year

At an instantaneous rate not exceeding 350 litres per second.

No issues were identified with the quantities recorded

7. Means of Measurement of Water Abstracted

The licence holder shall determine the quantity of water abstracted by reference to the kilowatt-hours generated, as measured by a kilowatt-hours meter multiplied by the conversion factor determined using a calculation checklist attached to the licence.

The licence holder shall retain supporting documentation relating to details of the methodology and calculations used to convert electricity generated to the quantities abstracted and make them available to the agency on request

No issues were identified

8. Records

The licence holder shall record readings of the electrical output and the corresponding quantity of water abstracted at the same time each week, as determined using the calculation checklist attached to the licence.

No issues were identified, returns have been received by Natural Resources Wales and abstraction quantities are within the permitted amounts.

9. Further Conditions

For the purpose of this licence, references to 'hydropower scheme' shall mean all works consisting of a new concrete weir Coanda intake screen with 2 millimeters bar spacing, pipe with internal diameter not exceeding 1000 millimeters, fish way with ponds, eel passage and a discharge pipe with bar screening with spacing not exceeding 25 millimeters

The licence holder shall construct, operate and maintain the hydropower scheme in accordance with the specifications and drawings

The flows were too high to take any measurements across the whole structure, but visually the structure has been built as per the specifications and drawings.

No abstraction shall take place unless the licence holder has installed a Coanda intake screen with spacing no greater than 2 millimeters to prevent the entrapment, entrainment or impingement of fish at the point of abstraction.

The licence holder shall maintain the fish screen in accordance with the manufacturer's specifications and keep records of such maintenance available for inspection.

No issues were identified

Prior to abstraction taking place for the purpose of power production under this licence, the licence holder shall construct an eel passage downstream of the weir at National Grid Reference SH 84281 31596 in accordance with plans specified in condition 3.2

No issues were identified

If you would like to discuss anything in this report please do not hesitate to contact me using the details below

Laura Jones

Uch Swyddog Amgylchedd/ Senior Environment Officer

Tim Amgylchedd Conwy/ Conwy Environment Team

Cyfoeth Naturiol Cymru / Natural Resources Wales

Ffon Symudol/Mobile Phone 07766248453

Siaradwr Cymraeg

Maes y Ffynnon, Penrhosgarnedd, Bangor, Gwynedd, LL57 2DW.

If you have any queries about this report, or to discuss completion of any actions, please contact the NRW Officer named above.

Important information

Legal status of this report

Your licence is issued to you under the Water Resources Act 1991 as amended by the Water Act 2003. You have a responsibility to comply with the conditions of your licence and prevent pollution/harm to the environment. You must also ensure that you comply with any other relevant legislation that may apply to your site's operations.

This report explains the findings of our assessment and any action you are required to take. We categorise non-compliance using our guidance for assessing non-compliance at regulated sites.

When we find potential non-compliance/s we will normally give you advice on how to maintain compliance.

To correct non-compliance, we may:

- require you to take specific actions
- issue a notice.

Any advice and guidance we give will be without prejudice to any other enforcement response that we consider may be required.

Assessment results and non-compliance categories (used in section 1):

Assessment result	Description
Assessed (A)	Assessed or assessed in part, no evidence of non-compliance found
Action only (X)	Action only relating to the activity assessment
Ongoing (O)	Ongoing non-compliance, not scored

Non-compliance category	Description
C1 Major	Potential to have a major, serious, persistent and/or extensive impact or effect on the environment, people and/or property
C2 Significant	Potential to have a significant impact or effect on the environment, people and/or property
C3 Minor	Potential to have a minor or minimal impact or effect on the environment, people and/or property
C4 No environmental impact	Non-compliance at a regulated site that cannot foreseeably have any impact on the environment, people and/or property

If your assessment result in Section 1 is suspended, what does this mean?

In line with our guidance, we may suspend non-compliance for up to six months to allow time for remedial action to be taken. These will be re-instated if the action is not completed.

Full list of Water resource action criteria (used in section 1 and 2):**WR A: Abstraction specified by Licence**

- WR-A1 Source of supply
- WR-A2 Points of abstraction
- WR-A3 Means of abstraction
- WR-A4 Purposes of abstraction
- WR-A5 Period of abstraction
- WR-A6 Quantities
- WR-A7 Land
- WR-A8 Other specified on licence

WR B: Abstraction measurement and records

- WR-B1 Means of measurement
- WR-B2 Recording
- WR-B3 Reporting

WR C: Surface / Groundwater level and protected flow

- WR-C1 Minimum hands-off flow/level requirements
- WR-C2 Flow/level measurement devices
- WR-C3 Recording
- WR-C4 Reporting

WR D: Environmental monitoring and information

- WR-D1 Recording
- WR-D2 Reporting
- WR-D3 Notifications

WR E: Fish and eel passage

- WR-E1 Infrastructure specified by licence
- WR-E2 Maintenance and records

WR F: Discharge

- WR-F1 Point of discharge
- WR-F2 Infrastructure
- WR-F3 Measurement
- WR-F4 Recording
- WR-F5 Reporting

WR G: Impoundment specified by licence

- WR-G1 Inland water to be impounded
- WR-G2 Manner and extent of impoundment
- WR-G3 Point(s) of impoundment
- WR-G4 Construction and removal requirements
- WR-G5 Other specified on licence

WR H: Borehole infrastructure

- WR-H1 Infrastructure and accessibility
- WR-H2 Maintenance and calibration

Enforcement response

Any licence condition non-compliance is an offence and we may take legal action against you. Action we take can include prosecution or civil sanctions. See our Enforcement and Sanctions Guidance for further information.

Data protection notice

You should make sure that anyone named in this report knows that the information it contains will be processed by Natural Resources Wales to fulfil its regulatory and monitoring functions and to maintain the relevant public register(s).

We may also use and/or disclose the report in connection with:

- offering or providing you with our literature or services relating to environmental matters
- consulting with the public, public bodies and other organisations (e.g. Health and Safety Executive, local authorities) on environmental issues
- carrying out statistical analysis, research and development on environmental issues
- providing public register information to enquirers
- investigating possible breaches of environmental law
- assessing customer service satisfaction and improving our service
- Freedom of Information Act or Environmental Information Regulations requests.

We may also pass it on to our agents or representatives to do these things on our behalf.

Disclosure of information – this report will be available to view on-line

If you think this report contains commercially confidential information that should not be placed on our public register, you must contact your local Natural Resources Wales office within **fifteen working days** of receiving this report, using the contact details in the accompanying email or letter. You must give a full explanation of why it should not be added to our public register, including specifying which information is commercially confidential. We will assess your request and respond to you within 20 working days to let you know if we agree to your request.

What do I do if I disagree with the report or have a complaint?

If you disagree with this compliance assessment report, you should contact the lead officer without delay to discuss your concerns.

If you are unable to resolve the issue with the lead officer or their line manager you should contact our Customer Contact team on 0300 065 3000 (Mon to Fri 08:00 – 18:00), or email enquiries@naturalresourceswales.gov.uk for details of how to raise your dispute further through our Complaints and Commendations procedure.

If you are dissatisfied with our response, you can contact the Public Services Ombudsman for Wales by phone on 0300 7900203 or by email at ask@ombudsman.wales

Welsh Language Standards

We are committed to establishing Natural Resources Wales as a naturally bilingual organisation. We will provide compliance reports in your preferred language.