



**ENVIRONMENT
AGENCY**

Consent to Discharge

Water Resources Act 1991 (as amended by the Environment Act 1995)

Consent Holder(s)

**Mr Neil Kedward and Ms Zoe Agar
The Grove
Molleston
Narberth
SA67 8BX**

Consent to Discharge from

**The Grove
Molleston
Narberth
SA67 8BX**

Consent Number

NPSWQD007571

Consent to Discharge

Water Resources Act 1991
Section 88, Schedule 10
(as amended by the
Environment Act 1995)



**ENVIRONMENT
AGENCY**

Consent to Discharge

Consent Number

NPSWQD007571

To:

Mr Neil Kedward and Ms Zoe Agar ("the Consent Holder(s)")

The Grove

Molleston

Narberth

SA67 8BX

The Environment Agency ("the Agency") in pursuance of its powers under the Water Resources Act 1991(as amended by the Environment Act 1995) hereby consents to the making of a discharge:

Of:

Secondary treated sewage effluent and trade effluent ("the Discharge")

From:

The sewage treatment plant serving one hotel and holiday let cottages

At:

The Grove, Molleston, Narberth

To:

Un-named tributary of Narberth stream

Subject to the conditions set out in this notice of Consent to Discharge.

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991(as amended by the Environment Act 1995), no notice shall be served by the Agency, altering this consent, without the agreement of the Consent Holder, during a period of 4 years from the date this notice is issued.

This Consent is granted and takes effect on: 25th September 2009

Signed

Christopher Hall

National Permitting Team Leader

1 **Conditions of Consent for secondary treated sewage effluent and trade effluent**

1.1 **Nature**

1.1.1 The Discharge shall consist solely of secondary treated sewage effluent and trade effluent.

1.2 **Place of Discharge**

1.2.1 The Discharge shall be made in the manner and at the place specified as:

- a** discharging to un-named tributary of Narberth stream;
- b** at National Grid Reference SN 09289 13061;
- c** shown marked "OUTLET AND SAMPLE POINT" on Site Plan attached to this consent.

1.3 **Sampling Point Requirements**

1.3.1 The outlet to controlled waters shall be constructed and maintained so that a representative sample of the Discharge may be obtained at National Grid Reference SN 09289 13061 as shown marked "OUTLET AND SAMPLE POINT" on the Site plan attached to this consent.

1.4 **Volume**

1.4.1 The volume of the Discharge shall not exceed 15.6 cubic metres per day.

1.5 **Composition**

1.5.1 The Discharge shall not contain more than:

- a** 20 milligrammes per litre of biochemical oxygen demand (measured after 5 days at 20°C with nitrification suppressed by the addition of allyl-thiourea)
- b** 30 milligrammes per litre of suspended solids (measured after drying at 105°C)
- c** 5 milligrammes per litre of ammoniacal nitrogen (expressed as N)

1.5.2 As far as is reasonably practicable, the sewage treatment plant shall be operated so as to prevent the Discharge from containing any visible oil or grease.

1.6 **Urban Waste Water Treatment Regulations**

1.6.1

- a** The Consent Holder shall comply with the Urban Waste Water Treatment (England and Wales) Regulations 1994 ('the Regulations').
- b** For the purpose of condition 1.6.2 below, interpretations and references to a numbered regulation or Schedule shall have the meaning as in the Regulations, unless otherwise indicated.

1.6.2

- a** The Discharge derives from an agglomeration with a population equivalent of less than 2,000 discharging to freshwaters.
- b** The Consent Holder shall inform the Agency in writing of any change, or proposed change, to the population equivalent such as would make a material change to the application of the Regulations and shall, on request, inform the Agency in writing of the actual population equivalent.
- c** The Discharge shall be subject to Regulation 5(7) and satisfy the requirements of Regulation 5(8)(a).

1.7 **British Standard**

- 1.7.1 The sewage treatment plant shall conform to all relevant British Standards in place at the time of installation.

1.8 **Works Operation**

- 1.8.1 The sewage treatment plant shall be operated and the effluent shall be treated in a manner which, so far as reasonably practicable, minimises the polluting effects of the discharge made from the plant on controlled waters.

This condition does not require -

- a** any higher standard to be achieved in relation to any characteristic of the Discharge which is specifically regulated by conditions 1.5.1 and 1.5.2 above than is required by those conditions;
- b** any alteration of the sewage treatment plant or a change in the type of treatment used.

1.9 **Maintenance**

- 1.9.1 The sewage treatment plant shall be operated and maintained in accordance with good operational practice such that:

- a** it remains fully operational except at times of unavoidable mechanical or electrical breakdown which shall be attended to, and the Agency informed of the failure, as soon as practicable after the failure;
- b** following a failure all equipment shall be returned to normal operation as soon as practicable;
- c** tanks shall be desludged at sufficient frequency and in such a manner to prevent excessive carryover of suspended solids.

1.10

Recording and Reporting

1.10.1

- a** The Consent Holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- b** On request the Consent Holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality.
- c** The Consent Holder shall as soon as reasonably practicable report to the Agency all non-routine actions that may have adversely affected effluent quality.

2

Site plan

