

CONSENT NO.	CG0376801
-------------	-----------



ASiantaeth Yr
Amgylchedd
Environment
Agency

WATER RESOURCES ACT 1991


SECTION 88 - SCHEDULE 10

(AS AMENDED BY THE ENVIRONMENT ACT 1995)

CONSENT TO DISCHARGE

TO: The Chief Executive
Wirral Borough Council
Wallasey Town Hall
Wallasey
Merseyside L44 8ED



The ENVIRONMENT AGENCY ("The Agency") in pursuance of its powers under the Water Resources Act 1991 HEREBY CONSENTS to the making of a discharge OF SEWAGE EFFLUENT, as follows:	
Biologically Treated Sewage Effluent	
FROM: Sewage Treatment Plant serving The Oaklands Centre	
AT: Capel Garmon Road, Llanrwst, Conwy	
TO: Afon Gallt-y-Gwg a tributary of the Afon Conwy	
SUBJECT TO the conditions set out in the following schedule(s):	
Biologically Treated Sewage Effluent	Schedule No. CG0376801 01
Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency, altering this consent, without the agreement in writing of the consent holder, during a period of 4 years from the date this consent takes effect.	
This consent is issued and takes effect on the 10th day of June 1998	
Signed  Team Leader - Water Quality Consents	



CONSENT NO.	CG0376801
SCHEDULE NO.	CG0376801 01
DATE ISSUED	10th June 1998



**ASiantaeth YR
AMGYLCHEDD
ENVIRONMENT
AGENCY**

CONDITIONS OF CONSENT TO DISCHARGE

Biologically Treated Sewage Effluent ("the Discharge")

FROM: Sewage Treatment Plant serving the Oaklands Centre, Capel Garmon Road, Llanrwst, Conwy

1. (a) The Discharge shall not contain any poisonous, noxious or polluting matter or solid waste matter.
- (b) Provided that the Discharge hereby consented is made in accordance with the following conditions of this consent, such discharge shall not be taken to be in breach of condition (a) above by reason of containing substances or having properties identified in and controlled by these conditions.

NATURE

2. The Discharge shall consist solely of biologically treated sewage effluent, containing no trade effluent, from the sewage treatment plant serving the Oaklands Centre, Capel Garmon Road, Llanrwst, Conwy

LOCATION

3. The Discharge shall be made in the manner and at the place specified as:
 - (a) discharging via a 150 millimetre pipe;
 - (b) discharging to Afon Gallt-y-Gwg a tributary of the Afon Conwy;
 - (c) at National Grid Reference SH 8110 5840;
 - (d) shown marked 'Discharge Point' on Plan CG0376801 attached as Annex 1.

SAMPLING POINTS

4. The outlet to the watercourse shall be constructed and maintained so that a representative sample of the Discharge may be obtained at National Grid Reference SH 8120 5840 as shown marked 'Sampling Point' on Plan CG0376801.



CONSENT NO.	CG0376801
SCHEDULE NO.	CG0376801 01



ASiantaeth YR
AMGYLCHEDD
ENVIRONMENT
AGENCY

VOLUME

5. The volume of the Discharge shall not exceed 8.1 cubic metres per day.

COMPOSITION

6. The Discharge shall not contain more than:
- (i) 40 milligrammes per litre of biochemical oxygen demand (measured after 5 days at 20°C with nitrification suppressed by the addition of allyl-thiourea);
 - (ii) 60 milligrammes per litre of suspended solids (measured after drying at 105°C).
7. As far as is reasonably practicable, the works shall be operated so as to prevent:
- (a) any matter being present in the Discharge, other than matter specifically covered by numerical conditions in this consent, to such an extent as to cause the receiving waters, or any waters of which the receiving waters are a tributary, to be poisonous or injurious to fish in those waters, or to the spawning grounds, spawn or food of fish in those waters, or otherwise cause damage to the ecology of those waters; and
 - (b) the Discharge from having any other adverse environmental impact.



CONSENT NO.	CG0376801
SCHEDULE NO.	CG0376801 01



ASiantaeth YR
AMGYLCHEDD
ENVIRONMENT
AGENCY

ANNEX 1

Plan CG0376801

