

Consent to Discharge Certificate of Holder



22 April 1997

Part A

To: CARMARTHENSHIRE COUNTY COUNCIL
DIRECTOR LEGAL & ADMIN SERVICE
COUNCIL OFFICES
3 SPILMAN STREET
CARMARTHEN SA31 1LE

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BG0020001

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at

DANRHELYG STW, NEWCASTLE EMLYN

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type:

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent: BG0020001
Name: CARMARTHENSHIRE COUNTY COUNCIL
Address: DIRECTOR LEGAL & ADMIN SERVICE
COUNCIL OFFICES
3 SPILMAN STREET
CARMARTHEN SA31 1LE

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed:

Dated:

Name (block capitals):

Position:

(to be completed when signing on behalf of corporate bodies)



REGISTER OF CONDITIONS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951.

BG 0020001

G.S. 1510.

200

Cat. No. R.R.12. Sewerage Dept., Freetown, G.C. 4. 17/1

<p>NAME AND ADDRESS OF APPLICANT Newcastle Endyn Rural District Council.</p>	<p>DATE OF APPLICATION 22nd December 1959</p>
<p>DATE ON WHICH CONDITIONS CAME INTO FORCE 11th January 1960.</p>	<p>FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE CONDITIONS RELATE Extension of Existing Sewage Disposal Works at Dumblyg Water.</p>
<p>USE OF NEW OR ALTERED OUTLET CONDITIONS IMPOSED WITH RESPECT TO:- (i) PRECISE LOCATION OF OUTLET O.S. Camp X111.6. Field No. 1118 off bank of tributary of River Gych. Nat. Grid. Ref.: SN 296 367. (17/15/41)</p>	<p>NEW DISCHARGE CONDITIONS IMPOSED WITH RESPECT TO:- (i) NATURE AND COMPOSITION OF DISCHARGE The B.O.D. (5 days 20°C) of W effluent not exceeding 20 ppm. suspended matter not exceeding 30 ppm. The effluent being well settled before stability test (5 days 20°C). The effluent being pH value being not less than 5 nor more than 10 ppm. nitrate (as N). The effluent being not so hot as to be injurious to fish or the spawning ground, riparian or food of fish. (ii) TEMPERATURE OF DISCHARGE Not exceeding 85°F.</p>
<p>(iii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) At existing outlet, above normal water level to facilitate sampling.</p>	<p>(iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES Not to exceed 1,100 gallons</p>
<p>(iii) USE OF OUTLET Discharge of treated Domestic Sewage Effluent only.</p>	<p>REMARKS:- Surface water being excluded from the disposal works, and Tanks to be desludged at frequent intervals.</p>
<p>(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES</p>	