

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	BV0767IT
Name of Operator	CELSA Manufacturing (UK) Ltd
Location of Installation	Seawall Road, Tremorfa, Cardiff CF24 5TH
Location of the emission	Seawall Road, Tremorfa, Cardiff CF24 5TH
Time and date of the emission	19/03/24

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Suspected Contaminated Rainwater	Water	Unknown	19/03/24

Measures taken, or intended to be taken, to stop the emission	Incident raised with Sections Mill senior management. Investigation to be carried out by operational team.
---	---

Part B

Any more accurate information on the matters for notification under Part A.	<p>The flooding in the Bar Mill Electrical Cellar was caused by rainwater ingress. The water in the cellar caused a surge which resulted in a high voltage breaker electrical trip.</p> <p>This presented a safety hazard to personnel in the area. To mitigate the immediate health and safety risk, an extraction pipe was run through the cellar and out onto the internal pathway outside the mill.</p> <p>The water pumped out of the cellar was not contained at the time of the incident.</p>
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>The extraction pipe was rerouted to a flume which redirected the water into the water treatment plant as soon as possible.</p> <p>A water sample was analysed on the same day by our onsite contractor. All results were within effluent consent limits.</p> <p>A sample was also sent to a UKAS accredited lab</p>

Schedule 1 - Notification of abnormal emissions

	<p>for analysis. All results were also within effluent consent limits.</p> <p>The Sections Mill management team are raising an environmental awareness point of this incident. This will be communicated to all engineers, production crafts and shift managers.</p>
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	N/A
The dates of any unauthorised emissions from the installation in the preceding 24 months.	N/A

Name*	[REDACTED]
Post	Environmental Advisor
Signature	[REDACTED]
Date	10/05/24

* Authorised to sign on behalf of CELSA Manufacturing (UK) Ltd.