

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: SNOWDONIA NATIONAL PARK AUTHORITY
PROPERTY MANAGER
NATIONAL PARK OFFICES

PENRHYNDEUDRAETH LL48 6LF



The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent CG0083301

Nature of Discharge(s): SEWAGE EFF/TREATED EFF/CONTINUOUS
at

TOILET BLOCK, PONT BETHANIA, NANTGWYNANT

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s);

Signed:

Dated:

Name (block capitals):

Position:



CONSENT NO.

CG0083301



ASiantaeth YR
AMGYLCHEDD
ENVIRONMENT
AGENCY

WATER RESOURCES ACT 1991

SECTION 88 - SCHEDULE 10

REPLACEMENT CONSENT

(for an application for the replacement of a consent which lapsed on 30 September 1996 under the provisions of Schedule 23 of the Environment Act 1995).

TO: Property Manager
Snowdonia National Park Authority
National Park Offices
Penrhyndeudraeth
Gwynedd LL48 6LF.

The **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY CONSENTS** to the making of a discharge **OF SEWAGE EFFLUENT** as follows:

Primary Treated Sewage Effluent

FROM: Toilet Block

AT: Pont Bethania, Nantgwynant, Gwynedd

TO: Afon Glaslyn

SUBJECT TO the conditions set out in the attached copy of the lapsed consent document:

Consent No. CG0083301 issued on the 18th day of May 1972

Subject to the provisions of Schedule 10 of the Water Resources Act 1991, in accordance with your agreement dated the 4th day of February 1997 the Agency may modify the conditions of this consent from the date this consent takes effect.

This consent is issued and takes effect on the 3rd day of March 1997

Signed
Area Water Quality Manager

Asiantaeth yr Amgylchedd

Llwyn Brain, Ffordd Penlan, Parc Menai, Bangor LL57 4DE. Ffon 01248 670770, Ffacs 01248 670561

Environment Agency

Llwyn Brain, Ffordd Penlan, Parc Menai, Bangor LL57 4DE. Tel 01248 670770, Fax 01248 670561



LAPSED 1-10-1996 UNDER
SCHEDULE 23.

CG 00 833 - 01

C.203/8. AJ/AL.
CV/1/2

18th May, 1972.

Dear Sir,

Rivers (Prevention of Pollution) Acts 1951-1961
Sewage Treatment Works to Serve Toilet Block at
Pont Bethania, Nant Gwynant.

With reference to your application of 8th March 1972, the Gwynedd River Authority, in pursuance of their powers under the above Acts, hereby consent to the bringing into use of a new outlet for the discharge of treated sewage effluent and the making of a new discharge of treated sewage effluent into the Afon Glaslyn at a point downstream of Pont Bethania in accordance with the plan submitted and subject to the following conditions:-

1. The volume of fully treated sewage effluent discharged under dry weather flow conditions shall not exceed 782 litres (150 gallons) in any period of 24 hours.
2. The treated sewage effluent discharged shall at no time:-
 - (a) Contain more than 30 milligrammes per litre suspended solids (dried at 105° C).
 - (b) Take up more than 20 milligrammes per litre of dissolved oxygen in 5 days at 20° C.
3. The outfall to the river shall be so constructed that samples of the effluent shall be readily taken by the Authority's officers.

The terms of this consent will not, without the consent in writing of the person to whom this consent is given (or his successor), be altered before the expiration of the period ending with the 31st day of May, 1974.

The Clerk,
Gwynedd Rural District
Council,
Cwallyn,
CAERNARVON.

Yours faithfully,


Clark of the Authority

Copy of letter sent to the County Planning Officer,
Caernarvonshire County Council, County Offices, Caernarvon.

Water Resources Act 1991
Schedule 10



ASiantaeth Yr
AMGYLCHEDD
ENVIRONMENT
AGENCY

Application for the replacement of a consent which lapsed on 30 September 1996
(Schedule 23 of the Environment Act 1995)

Consent Number: CG0083301

A) Name of applicant * SNOWDONIA NATIONAL PARK AUTHORITY
Address of applicant

NATIONAL PARK OFFICES
PENRYNDEUDRAETH
GWYNEDI

Post Code

LL48 6LF

< *If you are a body corporate please complete with the registered name/address of the body corporate - see also note below >

B) Name and address of site

< if different from above >

PONT BETHANIA TOILET BLOCK
NANTGWYNANT

C) I hereby apply to the Environment Agency ('the Agency') for a consent to replace the above consent which lapsed on 30 September 1996 for the making of a discharge of

TREATED SEWAGE EFFLUENT

to

Afon Glaslyn

I confirm that:

- (a) I was the holder of the above consent on 30 September 1996;
- (b) I agree that, if granted, the replacement consent may be reviewed by the Agency at any time, but no earlier than as allowed by the above lapsed consent;
- (c) I understand that, if granted, the Agency will issue a replacement consent containing the same conditions and requirements as the above lapsed consent.

Signed.....  Dated..... 4-2-97

Name..... PETER TRUMPER Day time tel: 01766 776 274
< in block capitals >

Job title..... PROPERTY MANAGER
< If signing on behalf of a body corporate >

Completed forms to be returned to:

Regional Consents and Compliance Manager, Rivers House, St Mellons Business Park, St Mellons, Cardiff CF3 0LT.
Tel 01222 770088, Fax 01222 798555 GTN 7-26 x1000

NOTE: In addition to an individual, a "person" in legal terms may refer to a "body corporate" (eg a public limited company, local authority or limited company). In these cases the body corporate should apply for the replacement consent. The person signing the application will be the person with the authority to do so, usually the company secretary for a PLC. The legal validity of the signatory is the responsibility of the corporate body. If you are signing with delegated authority please give your job title/position.



LAPSED 1-10-1996
UNDER SCHEDULE 23.

CG00 833 - 01

C.203/8. Ad/AL.
CV/4/24.

18th May, 1974.

Dear Sir,

Rivers (Reversion of Pollution) Acts 1951-1961
Sewage Treatment Works to Serve Toilet Block at
Pont Bethania, Nant Gwynant.

With reference to your application of 8th March 1972, the Gwynedd River Authority, in pursuance of their powers under the above Acts, hereby consent to the bringing into use of a new outlet for the discharge of treated sewage effluent and the making of a new discharge of treated sewage effluent into the Afon Glaslyn at a point downstream of Pont Bethania in accordance with the plan submitted and subject to the following conditions:-

1. The volume of fully treated sewage effluent discharged under dry weather flow conditions shall not exceed 782 litres (150 gallons) in any period of 24 hours.
2. The treated sewage effluent discharged shall at no time:-
 - (a) Contain more than 30 milligrammes per litre suspended solids (dried at 105° C).
 - (b) Take up more than 20 milligrammes per litre of dissolved oxygen in 5 days at 20° C.
3. The outfall to the river shall be so constructed that samples of the effluent shall be readily taken by the Authority's officers.

The terms of this consent will not, without the consent in writing of the person to whom this consent is given (or his successor), be altered before the expiration of the period ending with the 31st day of May, 1974.

The Clerk,
Gwyrfai Rural District
Council,
Cwellyn,
CAERNARVON.

Yours faithfully,


Clerk of the Authority

Copy of letter sent to the County Planning Officer,
Caernarvonshire County Council, County Offices, Caernarvon.