

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

21 April 1997

Part A

To: CYNGOR GWYNEDD COUNCIL
ARFON AREA HOUSING MANAGER
SWYDDFA ARDAL ARFON
PENRALLT
CAERNARFON LL55 1BN

CG0023701/02

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent CG0023701

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at

BRO ELIDIR STW, DINORWIC

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent: CG0023701
Name: CYNGOR GWYNEDD COUNCIL
Address: ARFON AREA HOUSING MANAGER
SWYDDFA ARDAL ARFON
PENRALLT
CAERNARFON LL55 1BN

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:



CG0023701_2006_03_02

Post Code:

Date of Transfer to new Holder(s):

Signed:

Dated:

Name (block capitals):

Position:



Adran Tai a Gwarchod y Cyhoedd
Housing and Public Protection Department

Cyfarwyddwr / Director · D P Lewis



Act

Gallwnwch am / Ask for: Mrs E. Williams
Ffôn uniongyrchol / Direct line: Ext. 4723

Ein cyf / Our ref: EW/GJ/AH130

Eich cyf / Your ref:

(4)

19th September 1996

Environment Agency
Rivers House
St. Mellons Business Park
CARDIFF
CF3 0LT

updated
11.12.96
Bex

* although 02 only listed by
Council - Mark Medway advised
to include 01 as probably an error
∴ amended 30.9.96 Bex *

Dear Sirs

DISCHARGE CONSENTS

I give notice to the Agency that I propose to rely on the consents listed below to keep the legal defence against a pollution offence that the consent provides:-

- 1) CG0322101 - Eithiog Pumping Station No. 1, Penrhosgarnedd, Bangor
- 136824 * CG0023701/02
- 2) CG023702 - Bro Elidir Treatment Works, Dinorwic
- 3) CG0075301 - Rhydfadog Treatment Works, Deiniolen

I will shortly be replacing the Maes Eilian Sewage Works, in Dinorwic and will be applying for discharge consent in due course.

Yours faithfully

Arfon Area Housing Manager

11264

MESSAGE DISPLAY FOR R.WILLIAMS

To R.WILLIAMS
CC RICHARD
CC JOHN

From: R.CARRINGTON Host: ST.MELLONS
Postmark: 10 March 1993 10:00 Delivered: 10 March 1993 10:06
Status: Certified Previously read
Subject: Reply to a reply: CG0023701/02

Reply text:

From: R.CARRINGTON:NRA_WALES
Date: 10 March 1993 10:00

YES, THE 01 SHOULD BE RE-ISSUED. THE PROBLEM WITH THE 02 IS THAT (a) POLLUTION CONTROL SHOULD NOT BE ALLOCATING NUMBERS THEMSELVES BECAUSE THIS MAY LEAD TO DUPLICATION AS WE HAVE NO RECORD AND (b) IF CONSENTS ARE TO BE ISSUED WITHOUT APPLICATION THERE ARE SPECIFIC PROVISIONS IN THE ACT TO COVER THIS, ONE OF WHICH IS THAT ALL SUCH CONSENTS SHOULD BE ADVERTISED, WHICH WELSH WATER APPARENTLY ARE NOT HAPPY ABOUT AS IT COSTS THEM MORE MONEY WHEN THEY COULD HAVE JUST WRITTEN IN AND ASKED FOR CONSENT. THEY ALSO DISLIKE THE PUBLICITY.

APART FROM THAT, IF CONSENTS ARE TO BE ISSUED WITHOUT APPLICATION THEN THE CONSENTS SECTION SHOULD BE INFORMED SO THAT WE CAN KEEP TRACK OF THINGS, RATHER THAN THEM JUST COMING THROUGH AS ISSUED CONSENTS. I APPRECIATE THAT I COULD HAVE PICKED THIS UP WHEN I CHECKED THE DRAFTS, BUT AS THIS WAS A NEW CONSENT I ASSUMED ALL WAS OK. I'LL MAKE SURE I CHECK ALL DRAFTS ON DISCHARGE IN FUTURE INCASE ANYTHING SLIPS THROUGH.

ALSO, WE HAVE THE AUDITORS IN THIS WEEK AND JOHN TOLD THEM YESTERDAY THAT PC DON'T ISSUE CONSENTS WITHOUT FOLLOWING THE CORRECT PROCEDURES!! THIS ONE IS NOW ON DISCHARGE AND OK. I DON'T ACTUALLY DEAL WITH THE APPLICATIONS AT THE BEGINNING SO ANY HELP TO AVOID A SIMILAR SITUATION AGAIN WOULD BE APPRECIATED. THANKS ALOT. BECKY

Preceding message:

From: R.WILLIAMS:NRA_WALES
Date: 10 March 1993 09:44

In answer to the first part of your query, Consent CG00237-01 has been issued with the expiry date of the previous consent. This date should really be 10th February 1964.

-----X-----

MESSAGE DISPLAY FOR R.WILLIAMS

To ROSEMARY

From: R.CARRINGTON Host: ST.MELLONS
Postmark: 10 March 1993 09:02 Delivered: 10 March 1993 09:08
Status: Certified Previously read Urgent
Subject: CG0023701/02

Message:

ROSEMARY,

I HAVE JUST RECEIVED THESE TWO THROUGH TO PUT ONTO DISCHARGE.
CAN YOU CLARIFY A COUPLE OF POINTS ON THEM FOR ME? CG0023701 IS A
REVIEW WHICH DOES NOT REFER TO THE EARLIER ISSUE DATE ON THE
COMPUTER. IS THIS AN ERROR OR IS THERE AN ISSUE MISSING OFF
DISCHARGE? CG0023702 SEEMS OK, BUT ALTHOUGH I CHECKED THE DRAFT, THE
CONSENT DID NOT GO THROUGH NORMAL APPLICATION PROCEDURES. I ASSUME
THERE IS A REASON, BUT COULD YOU CHECK FOR ME? THEY ARE A BIT
CONFUSING BECAUSE THEY WERE GIVEN NEW CONSENT NUMBERS ORIGINALLY BY
GARY AND THEY SHOULDN'T HAVE BEEN (CG0338401/02).
IF YOU COULD HELP I'D BE GRATEFUL. THANKS.
BL

-----X-----



Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru

National Rivers Authority
Welsh Region

Consent No.	CG0023701
-------------	-----------

WATER RESOURCES ACT 1991

Under Section 88 and Schedule 10 of the Water Resources Act 1991 and all other enabling powers the National Rivers Authority hereby serves this Notice

REVIEW OF CONSENT

Page 1 of 2

On: Arfon Borough Council

Of: Swyddfa Arfon, Penrallt, Caernarfon, Gwynedd.

In respect of the previous Consent No. CG 0023701 issued on : 1st March 1966

For: A discharge of treated sewage effluent.

From: Bro Elidir Sewage Treatment Works

THE FOLLOWING REPLACE ALL PREVIOUS CONDITIONS

1. The discharge shall be made in the manner and at the place specified as follows:-

Discharging via : a 160mm diameter pipe

Discharging to : an un-named tributary of the Afon Fachwen

At OS Grid Ref : SH 5839 6166

As shown marked : Consent Point on the attached plan no. CG0023701

2. Adequate facilities approved in writing by the Authority, shall be provided to enable representative samples of the discharge to be safely and conveniently obtained at any time at the outlet pipe as shown marked 'Sampling Point' on the attached plan no. CG0023701.
3. The volume of effluent discharged under dry weather flow conditions shall not exceed 7 cubic metres per day.
4. The maximum rate of flow of effluent discharged shall not exceed 0.5 litres per second.

continued.....

Aelod Rhanbarthol o'r Bwrdd
Yr Athro Ron Edwards

Rheolwr Rhanbarth Cyffredinol
Dr John Stoner

Highfield, Ffordd Priestley
Caernarfon
Gwynedd, LL55 1HR
Ffon: Caernarfon (0286) 672247
Ffacs: (0286) 4451

Regional Board Member
Professor Ron Edwards

Regional General Manager
Dr John Stoner

Highfield, Priestley Road
Caernarfon
Gwynedd, LL55 1HR
Tel: Caernarfon (0286) 672247
Fax: (0286) 4451



*Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru*

*National Rivers Authority
Welsh Region*

Consent No.	CG0023701
-------------	-----------

**WATER RESOURCES ACT 1991
Continuation Sheet**

Page 2 of 2

5. The maximum volume of effluent discharged shall not exceed 20 cubic metres per day.
6. The quality of effluent discharged at all flow rates up to the maximum specified in condition 5. shall not be inferior to the following numerical limits:
- (i) The 5 day Biological Oxygen Demand (BOD ATU), determined at 20 degrees Celsius after the suppression of nitrification using allyl thiouria, shall not exceed 50 milligrammes per litre.
- (ii) The Suspended Solids concentration (dried at 105 degrees Celsius) shall not exceed 60 milligrammes per litre.

This notice is served on: 15th February 1993
Authority by:

on behalf of the
Area Environmental Quality manager.

During the period ending with the: 14th February 1995 the terms of this Consent will not be altered without the written agreement of the person making this discharge.

Aelod Rhanbarthol o'r Bwrdd
Yr Athro Ron Edwards

Rheolwr Rhanbarth Cyffredinol
Dr John Stoner

Highfield, Ffordd Priestley
Caernarfon
Gwynedd, LL55 1HR
Ffôn: Caernarfon (0286) 672247
Ffacs: (0286) 4451

Regional Board Member
Professor Ron Edwards

Regional General Manager
Dr John Stoner

Highfield, Priestley Road
Caernarfon
Gwynedd, LL55 1HR
Tel: Caernarfon (0286) 672247
Fax: (0286) 4451

GWYNEDD RIVER BOARD

RIVERS (PREVENTION OF POLLUTION) ACT 1961—SECTION 1 CONSENT TO A PRE-1951 DISCHARGE

CGCC-337-01

To:

The Clerk,
Gwyrfai Rural District Council,
Gwellyn,
Caernarvon.

Re: Treated Sewage Effluent Discharge - Dinorwic No. 2 Sewage Disposal Works
(Ordinance Survey Enclosure No. 3784a)

The GWYNEDD RIVER BOARD HEREBY CONSENT under sub-section (4) of Section 1 of the Rivers (Prevention of Pollution) Act 1961 to the continuance of a discharge of trade or sewage effluent which commenced before 1st October 1951 to a stream within the area of the Board, viz: **to that stream in Ordinance Survey Enclosure No. 3784a.**

This Consent is given subject to the following conditions:

1. The treated sewage effluent discharged shall at no time:-
 - (a) Contain suspended solids in excess of 30 parts per million (dried at 105° C).
 - (b) Take up more than 20 parts per million of dissolved oxygen in 5 days at 20° C.
 - (c) Contain any matter to such an extent as to cause the stream water to be poisonous or injurious to fish, fish spawn or the food of fish.
2. The volume of treated effluent discharged shall not exceed 1,500 gallons (dry weather flow) in any period of 24 hours.
3. Sampling facilities being provided and maintained at the outlet pipe to the stream.

The terms of this consent will not, without the consent in writing of the person to whom this consent is given (or his successor), be altered before the expiration of the period ending with the **1st** day of **March** 19 **66**.

Highfield,
Caernarvon.

[Signature]
Clerk of the Board.

10 FEB 1964.....19....

Attention is drawn to the extracts from the Act printed on the back of this consent.



*Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru*

*National Rivers Authority
Welsh Region*

WATER RESOURCES ACT 1991

Consent No. CG0023701

Under Section 88 and Schedule 10 of the Water Resources Act 1991 and all other enabling powers the National Rivers Authority hereby serves this Notice

REVIEW OF CONSENT

Page 1 of 2

On: Arfon Borough Council

Of: Swyddfa Arfon, Penrallt, Caernarfon, Gwynedd.

In respect of the previous Consent No. CG 0023701 issued on : 10th February 1964

For: A discharge of treated sewage effluent.

From: Bro Elidir Sewage Treatment Works

THE FOLLOWING REPLACE ALL PREVIOUS CONDITIONS

1. The discharge shall be made in the manner and at the place specified as follows:-

Discharging via : a 160mm diameter pipe

Discharging to : an un-named tributary of the Afon Fachwen

At OS Grid Ref : SH 5839 6166

As shown marked : Consent Point on the attached plan no. CG0023701

2. Adequate facilities approved in writing by the Authority, shall be provided to enable representative samples of the discharge to be safely and conveniently obtained at any time at the outlet pipe as shown marked 'Sampling Point' on the attached plan no. CG0023701.
3. The volume of effluent discharged under dry weather flow conditions shall not exceed 7 cubic metres per day.
4. The maximum rate of flow of effluent discharged shall not exceed 0.5 litres per second.

continued.....

Aelod Rhanbarthol o'r Bwrdd
Yr Athro Ron Edwards

Regional Board Member
Professor Ron Edwards

Rheolwr Rhanbarth Cyffredinol
Dr John Stoner

Regional General Manager
Dr John Stoner

Highfield, Ffordd Priestley
Caernarfon
Gwynedd, LL55 1HR
Ffôn: Caernarfon (0286) 672247
Ffacs: (0286) 4451

Highfield, Priestley Road
Caernarfon
Gwynedd, LL55 1HR
Tel: Caernarfon (0286) 672247
Fax: (0286) 4451



*Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru*

*National Rivers Authority
Welsh Region*

Consent No.	CG0023701
-------------	-----------

**WATER RESOURCES ACT 1991
Continuation Sheet**

Page 2 of 2

5. The maximum volume of effluent discharged shall not exceed 20 cubic metres per day.
6. The quality of effluent discharged at all flow rates up to the maximum specified in condition 5. shall not be inferior to the following numerical limits:
- (i) The 5 day Biological Oxygen Demand (BOD ATU), determined at 20 degrees Celsius after the suppression of nitrification using allyl thiouria, shall not exceed 50 milligrammes per litre.
- (ii) The Suspended Solids concentration (dried at 105 degrees Celsius) shall not exceed 60 milligrammes per litre.

Whereas this notice was given on 15th February 1993 on behalf of the Authority by A.G.Dixon, Area Environmental Quality Manager.

This notice is now reissued on 10th March 1993 on behalf of the Authority by: Area Environmental Quality manager.

During the period ending with the 14th February 1995 the terms of this Consent will not be altered without the written agreement of the person making this discharge.

Aelod Rhanbarthol o'r Bwrdd
Yr Athro Ron Edwards

Regional Board Member
Professor Ron Edwards

Rheolwr Rhanbarth Cyffredinol
Dr John Stoner

Regional General Manager
Dr John Stoner

Highfield, Ffordd Priestley
Caernarfon
Gwynedd, LL55 1HR
Ffôn: Caernarfon (0286) 672247
Ffacs: (0286) 4451

Highfield, Priestley Road
Caernarfon
Gwynedd, LL55 1HR
Tel: Caernarfon (0286) 672247
Fax: (0286) 4451

Bro Elidir S.T.W.

Plan No. GG0023701

