

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [June 2024](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.1	0.1	04/04/2024
Suspended Solids mg/l	50	5	18	04/04/2024
Mineral oil and hydrocarbons mg/l	5	0.1	0.1	09/05/2024
Suspended Solids mg/l	50	8	6	09/05/2024
Mineral oil and hydrocarbons mg/l	5	0.267	0.267	18/06/2024
Suspended Solids mg/l	50	6	5	18/06/2024

Signed on behalf of the Operator:

Date: 30/07/2024



Schedule 3 - Form Number: S1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [March 2023](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95th Percentile Value	Maximum
pH	6-11	6.10	7.22	9.32	9.50
Total suspended solids mg/l	600	19.00	61.23	126.60	144.00
Total chemical oxygen demand (COD) mg/l	3600	226.00	459.77	891.20	1,100.00
Free or emulsified grease or oil mg/l	100	5.71	18.09	30.28	31.60
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.50	0.52	0.64	0.70
Ammoniacal nitrogen as N mg/l	30	1.82	12.13	27.66	29.40
Daily flow m ³ /day	800	87.91	455.78	698.61	769.47
Maximum flow m ³ /h	34	3.66	18.99	29.11	32.06

Signed on behalf of the Operator:

Date: 30/07/2024

