

Reporting of Emission to Groundwater for the period from 1st January 2024 to 30th June 2024.

Operator : RWE Generation UK plc

Form: Water1

Location: Aberthaw Quarry Ash Disposal Site

Permit/Variation Number: BP3339BH

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SW12	Aluminium, Dissolved		9.9 µg/l		05/03/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		1.3 µg/l				
	Boron, Dissolved		666 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		189 mg/l				
	Chromium, Dissolved		5.0 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		28 mg/l				
	Manganese, Dissolved		9.6 µg/l				
	Molybdenum, Dissolved		856 µg/l				
	Nickel, Dissolved		3.9 µg/l				
	Selenium Dissolved		12.1 µg/l				
	Vanadium, Dissolved		3.3 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		148 mg/l				
	Electrical Conductivity at 20C		1560 mS/cm				
	Potassium, Dissolved		25 mg/l				
	Sodium, Dissolved		147 mg/l				
	Sulphate, Dissolved		341 mg/l				
	Total Oxidised Nitrogen		10.8 mg/l				
	Chloride		178 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		<0.41 mg/l				
	Total Organic Carbon		1.5 mg/l				
	Nitrate		10.6 mg/l				
	pH		8.2 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SW12	Aluminium, Dissolved		3.8 µg/l		30/05/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		1.4 µg/l				
	Boron, Dissolved		827 µg/l				
	Cadmium, Dissolved		0.0 µg/l				
	Calcium, Dissolved		234 mg/l				
	Chromium, Dissolved		6.1 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		34 mg/l				
	Manganese, Dissolved		0.5 µg/l				
	Molybdenum, Dissolved		1800 µg/l				
	Nickel, Dissolved		3.9 µg/l				
	Selenium Dissolved		22.3 µg/l				
	Vanadium, Dissolved		3.1 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO ₃		116 mg/l				
	Electrical Conductivity at 20C		2370 mS/cm				
	Potassium, Dissolved		32 mg/l				
	Sodium, Dissolved		223 mg/l				
	Sulphate, Dissolved		603 mg/l				
	Total Oxidised Nitrogen		12.9 mg/l				
	Chloride		387 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		<0.41 mg/l				
	Total Organic Carbon		3.5 mg/l				
	Nitrate		12.5 mg/l				
	pH		7.7 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		12.9 µg/l		06/02/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	3.4 µg/l				
	Boron, Dissolved	2000	1410 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		376 mg/l				
	Chromium, Dissolved	50	17.6 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		48 mg/l				
	Manganese, Dissolved		22.3 µg/l				
	Molybdenum, Dissolved		2380 µg/l				
	Nickel, Dissolved		9.0 µg/l				
	Selenium Dissolved		39.1 µg/l				
	Vanadium, Dissolved	60	9.1 µg/l				
	Mercury, Dissolved		0.0 µg/l				
	Total Alkalinity as CaCO3		191 mg/l				
	Electrical Conductivity at 20C		3270 mS/cm				
	Potassium, Dissolved		47 mg/l				
	Sodium, Dissolved		385 mg/l				
	Sulphate, Dissolved	400	755 mg/l				
	Total Oxidised Nitrogen		28.5 mg/l				
	Chloride		593 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen	0.6	3.3 mg/l				
	Total Organic Carbon		2.0 mg/l				
	Nitrate		27.1 mg/l				
	pH	<9	7.9 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		11 µg/l		05/03/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		1.4 µg/l				
	Arsenic Dissolved	50	2.4 µg/l				
	Boron, Dissolved	2000	980 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		251 mg/l				
	Chromium, Dissolved	50	10.9 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		34 mg/l				
	Manganese, Dissolved		20.7 µg/l				
	Molybdenum, Dissolved		1540 µg/l				
	Nickel, Dissolved		7.2 µg/l				
	Selenium Dissolved		21.4 µg/l				
	Vanadium, Dissolved	60	5.7 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		197 mg/l				
	Electrical Conductivity at 20C		2240 mS/cm				
	Potassium, Dissolved		34 mg/l				
	Sodium, Dissolved		225 mg/l				
	Sulphate, Dissolved	400	484 mg/l				
	Total Oxidised Nitrogen		19.8 mg/l				
	Chloride		325 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen	0.6	2.9 mg/l				
	Total Organic Carbon		1.8 mg/l				
	Nitrate		19.0 mg/l				
	pH	<9	8.1 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		19.0 µg/l		02/04/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	2.9 µg/l				
	Boron, Dissolved	2000	1160 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		315 mg/l				
	Chromium, Dissolved	50	13.3 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		40 mg/l				
	Manganese, Dissolved		34.2 µg/l				
	Molybdenum, Dissolved		2140 µg/l				
	Nickel, Dissolved		7.8 µg/l				
	Selenium Dissolved		31.9 µg/l				
	Vanadium, Dissolved	60	6.9 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		209 mg/l				
	Electrical Conductivity at 20C		2780 mS/cm				
	Potassium, Dissolved		36 mg/l				
	Sodium, Dissolved		302 mg/l				
	Sulphate, Dissolved	400	632 mg/l				
	Total Oxidised Nitrogen		23.3 mg/l				
	Chloride		463 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen	0.6	5.3 mg/l				
	Total Organic Carbon		24.1 mg/l				
	Nitrate		22.8 mg/l				
	pH	<9	7.2 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		13.1 µg/l		02/05/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	2.8 µg/l				
	Boron, Dissolved	2000	1030 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		277 mg/l				
	Chromium, Dissolved	50	12.9 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		36 mg/l				
	Manganese, Dissolved		27.6 µg/l				
	Molybdenum, Dissolved		1840 µg/l				
	Nickel, Dissolved		6.6 µg/l				
	Selenium Dissolved		27.3 µg/l				
	Vanadium, Dissolved	60	7.6 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		173 mg/l				
	Electrical Conductivity at 20C		2500 mS/cm				
	Potassium, Dissolved		34 mg/l				
	Sodium, Dissolved		266 mg/l				
	Sulphate, Dissolved	400	590 mg/l				
	Total Oxidised Nitrogen		19.6 mg/l				
	Chloride		418 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen	0.6	3.4 mg/l				
	Total Organic Carbon		13.3 mg/l				
	Nitrate		18.8 mg/l				
	pH	<9	7.8 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		17 µg/l		30/05/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	3.7 µg/l				
	Boron, Dissolved	2000	2050 µg/l				
	Cadmium, Dissolved	5	<0.2 µg/l				
	Calcium, Dissolved		500 mg/l				
	Chromium, Dissolved	50	16.8 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		51 mg/l				
	Manganese, Dissolved		30.6 µg/l				
	Molybdenum, Dissolved		3910 µg/l				
	Nickel, Dissolved		8.8 µg/l				
	Selenium Dissolved		54.9 µg/l				
	Vanadium, Dissolved	60	10.1 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		150 mg/l				
	Electrical Conductivity at 20C		4510 mS/cm				
	Potassium, Dissolved		65 mg/l				
	Sodium, Dissolved		564 mg/l				
	Sulphate, Dissolved	400	1090 mg/l				
	Total Oxidised Nitrogen		30.4 mg/l				
	Chloride		879 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen	0.6	7.5 mg/l				
	Total Organic Carbon		2.7 mg/l				
	Nitrate		28.5 mg/l				
	pH	<9	7.9 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		16 µg/l		25/06/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	3.7 µg/l				
	Boron, Dissolved	2000	2190 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		491 mg/l				
	Chromium, Dissolved	50	17.4 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		56 mg/l				
	Manganese, Dissolved		9.7 µg/l				
	Molybdenum, Dissolved		4650 µg/l				
	Nickel, Dissolved		9.7 µg/l				
	Selenium Dissolved		59.0 µg/l				
	Vanadium, Dissolved	60	11.1 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		141 mg/l				
	Electrical Conductivity at 20C		4980 mS/cm				
	Potassium, Dissolved		79 mg/l				
	Sodium, Dissolved		605 mg/l				
	Sulphate, Dissolved	400	1190 mg/l				
	Total Oxidised Nitrogen		35.2 mg/l				
	Chloride		1050 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen	0.6	8.5 mg/l				
	Total Organic Carbon		3.3 mg/l				
	Nitrate		33.0 mg/l				
	pH	<9	7.9 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		39 µg/l		06/02/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		1.5 µg/l				
	Arsenic Dissolved		5.2 µg/l				
	Boron, Dissolved		1920 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		423 mg/l				
	Chromium, Dissolved		26.7 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		59 mg/l				
	Manganese, Dissolved		46.1 µg/l				
	Molybdenum, Dissolved		3020 µg/l				
	Nickel, Dissolved		11.0 µg/l				
	Selenium Dissolved		53.7 µg/l				
	Vanadium, Dissolved		12.8 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		188 mg/l				
	Electrical Conductivity at 20C		3360 mS/cm				
	Potassium, Dissolved		50 mg/l				
	Sodium, Dissolved		361 mg/l				
	Sulphate, Dissolved		885 mg/l				
	Total Oxidised Nitrogen		33.0 mg/l				
	Chloride		549 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		6.9 mg/l				
	Total Organic Carbon		1.3 mg/l				
	Nitrate		32.0 mg/l				
	pH		7.2 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		19 µg/l		05/03/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		2.4 µg/l				
	Boron, Dissolved		974 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		273 mg/l				
	Chromium, Dissolved		11.9 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		24.0 µg/l				
	Magnesium, Dissolved		35 mg/l				
	Manganese, Dissolved		27.9 µg/l				
	Molybdenum, Dissolved		1580 µg/l				
	Nickel, Dissolved		7.5 µg/l				
	Selenium Dissolved		23.4 µg/l				
	Vanadium, Dissolved		5.7 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		220 mg/l				
	Electrical Conductivity at 20C		2360 mS/cm				
	Potassium, Dissolved		32 mg/l				
	Sodium, Dissolved		229 mg/l				
	Sulphate, Dissolved		456 mg/l				
	Total Oxidised Nitrogen		23.5 mg/l				
	Chloride		348 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		4.1 mg/l				
	Total Organic Carbon		1.6 mg/l				
	Nitrate		22.9 mg/l				
	pH		7.7 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		19.0 µg/l		02/04/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		2.9 µg/l				
	Boron, Dissolved		1160 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		315 mg/l				
	Chromium, Dissolved		13.3 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		40 mg/l				
	Manganese, Dissolved		34.2 µg/l				
	Molybdenum, Dissolved		2140 µg/l				
	Nickel, Dissolved		7.8 µg/l				
	Selenium Dissolved		31.9 µg/l				
	Vanadium, Dissolved		6.9 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		209 mg/l				
	Electrical Conductivity at 20C		2780 mS/cm				
	Potassium, Dissolved		36 mg/l				
	Sodium, Dissolved		302 mg/l				
	Sulphate, Dissolved		632 mg/l				
	Total Oxidised Nitrogen		23.3 mg/l				
	Chloride		463 mg/l				
	Fluoride		0.2 mg/l				
	Ammoniacal Nitrogen		5.3 mg/l				
	Total Organic Carbon		24.1 mg/l				
	Nitrate		22.8 mg/l				
	pH		7.2 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		26 µg/l		02/05/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		5.1 µg/l				
	Boron, Dissolved		1590 µg/l				
	Cadmium, Dissolved		<0.2 µg/l				
	Calcium, Dissolved		410 mg/l				
	Chromium, Dissolved		20.5 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		49 mg/l				
	Manganese, Dissolved		65.7 µg/l				
	Molybdenum, Dissolved		2880 µg/l				
	Nickel, Dissolved		9.2 µg/l				
	Selenium Dissolved		49.3 µg/l				
	Vanadium, Dissolved		11.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		159 mg/l				
	Electrical Conductivity at 20C		3530 mS/cm				
	Potassium, Dissolved		48 mg/l				
	Sodium, Dissolved		410 mg/l				
	Sulphate, Dissolved		911 mg/l				
	Total Oxidised Nitrogen		29.2 mg/l				
	Chloride		625 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		6.2 mg/l				
	Total Organic Carbon		2.1 mg/l				
	Nitrate		27.9 mg/l				
	pH		7.6 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		24 µg/l		30/05/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		4.4 µg/l				
	Boron, Dissolved		1770 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		491 mg/l				
	Chromium, Dissolved		21.2 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		50 mg/l				
	Manganese, Dissolved		68.2 µg/l				
	Molybdenum, Dissolved		4470 µg/l				
	Nickel, Dissolved		10.0 µg/l				
	Selenium Dissolved		60.9 µg/l				
	Vanadium, Dissolved		12.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		161 mg/l				
	Electrical Conductivity at 20C		4640 mS/cm				
	Potassium, Dissolved		63 mg/l				
	Sodium, Dissolved		523 mg/l				
	Sulphate, Dissolved		1150 mg/l				
	Total Oxidised Nitrogen		32.5 mg/l				
	Chloride		860 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		12.1 mg/l				
	Total Organic Carbon		1.7 mg/l				
	Nitrate		31.4 mg/l				
	pH		7.1 pH Units				

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		42 µg/l		25/06/2024	Sampling Station / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		4.2 µg/l				
	Boron, Dissolved		2360 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		578 mg/l				
	Chromium, Dissolved		18.9 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		53 mg/l				
	Manganese, Dissolved		77.3 µg/l				
	Molybdenum, Dissolved		4980 µg/l				
	Nickel, Dissolved		10.0 µg/l				
	Selenium Dissolved		61.7 µg/l				
	Vanadium, Dissolved		11.9 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO ₃		162 mg/l				
	Electrical Conductivity at 20C		5090 mS/cm				
	Potassium, Dissolved		78 mg/l				
	Sodium, Dissolved		638 mg/l				
	Sulphate, Dissolved		1230 mg/l				
	Total Oxidised Nitrogen		36.7 mg/l				
	Chloride		1040 mg/l				
	Fluoride		0.3 mg/l				
	Ammoniacal Nitrogen		14.3 mg/l				
	Total Organic Carbon		1.4 mg/l				
	Nitrate		35.6 mg/l				
	pH		7.3 pH Units				

[1] The result given is the maximum value (or the minimum value in the case of a limit that is fdpressed as a minimum) obtained during the reporting period, fdpressed in the same terms as the

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
----------------	-------------------------	-------------------------	-----------------------	-------------------------------	---	--	-------------------------------

[6] The emission limit values for all substances is fdpressed as a maximum individual value, unless otherwise stated.

Signed

ate

02/08/2024

(authorised to sign as representative of the Operator)