

WELSH OFFICE

CONTROL OF POLLUTION ACT 1974: SECTIONS 34 AND 55
THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES) REGULATIONS 1984
CONSENT FOR A DISCHARGE

1. The Welsh Water Authority (hereinafter referred to as 'the Water Authority') proposes to discharge sewage effluent from the Parc Sewage Treatment Works to the Afon Llafar at National Grid Reference SH 8774 3388 in accordance with the application dated 6 October 1987.
2. The proposal requires the consent of the Secretary of State for Wales in pursuance of sections 34 and 55 of the Control of Pollution Act 1974 and the Control of Pollution (Discharges by Authorities) Regulations 1984.
3. THE SECRETARY OF STATE FOR WALES hereby consents to the proposed discharge subject to the discharge conforming at all times to the terms of the certificate attached hereto.

Dated this *sixteenth* day of
November 1987

Signed 
on behalf of the Secretary
of State for Wales

THE CONTROL OF POLLUTION ACT 1974: SECTION 34
THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES)
REGULATIONS 1984 (SI 1984 NO 1200)

CERTIFICATE TO BE SUBMITTED WITH A REQUEST FOR A
DESCRIPTIVE DISCHARGE CONSENT

On behalf of the Welsh Water Authority we certify that, in respect of the
discharge from the Authority's sewage treatment works at PARC

(National Grid Reference SH 877 339).

1. The effluent derives from domestic sewage from a population of 250
or less and contains no authorised trade waste.
2. There are no potable water supply intakes downstream which are likely to
be adversely affected.
3. As far as is reasonably practicable, the works shall be operated so as to
prevent:
 - i any matter being present in the effluent which will cause the
receiving water to be poisonous or injurious to fish or to their
spawn or spawning grounds or food or otherwise cause damage to the
ecology of the receiving waters; and
 - ii the treated effluent from having any adverse visual and other
environmental impact.
4. The authority will operate the works having regard so far as is relevant,
to the guidance set out in the National Water Council's Occasional
Technical Paper Number 4, "The Operation and Maintenance of Small Sewage
Works" dated January 1980. In particular the works shall be maintained
properly such that:
 - a. it remains fully operational except at times of mechanical or
electrical breakdown;
 - b. any such breakdowns shall be attended to promptly and the equipment
returned to normal operation as soon as possible; and
 - c. tanks shall be desludged at sufficient frequency and in such a
manner as to present problems with septic sludge, rising sludge for
excessive carryover of suspended solids.

Signed [Signature]
(Name)
Divisional Operations Manager

Signed A. Harrell Jones
(Name)
District Scientist

Dated this 10th October 1987
Day of