

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [September 2024](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.327	0.393	04/07/2024
Suspended Solids mg/l	50	8	5	04/07/2024
Mineral oil and hydrocarbons mg/l	5	0.267	0.353	01/08/2024
Suspended Solids mg/l	50	1	6	01/08/2024
Mineral oil and hydrocarbons mg/l	5	0.92	1.04	19/09/2024
Suspended Solids mg/l	50	18	16	19/09/2024

Signed on behalf of the Operator:

Date: 22/10/2024



Schedule 3 - Form Number: S1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [September 2024](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95th Percentile Value	Maximum
pH	6-11	6.10	6.45	7.24	7.30
Total suspended solids mg/l	600	10	42.62	110	116
Total chemical oxygen demand (COD) mg/l	3600	126	262.15	447.80	539
Free or emulsified grease or oil mg/l	100	2.46	9.71	22.26	35.40
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.5	0.52	0.6	0.6
Ammoniacal nitrogen as N mg/l	30	2.69	8.28	14.88	17.10
Daily flow m ³ /day	800	54.42	485.26	685.99	728.37
Maximum flow m ³ /h	34	2.27	20.22	28.58	30.35

Signed on behalf of the Operator:

Date: 22/10/2024

