

NRW Permit Number: PAN-012754	Operator: Photronics UK LTD
Facility: CHP at Photronics UK LTD, 1 Technology Drive, Bridgend, CF31 3LU	Form Number: Air1

Reporting of emissions to air for the period from 10/06/2021 to 10/06/2021

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result	Test Method	Sample Date and Times
Inside the CHP container, upstream of the Exhaust gas heat exchanger.	Oxides of Nitrogen (NO and NO2 expressed as NO2)	95 mg/m ³	In line with TGN M5	93	RASI 800 Analyser-S/N 017232	10/06/21 at 1215
	Carbon monoxide	No limit set	In line with TGN M5	258	RASI 800 Analyser-S/N 017232	10/06/21 at 1215

Signed

(Authorised to sign as representative of Operator)

Date

14/6/2021