

Permit Number: PAN-013278 Operator: G T S Flexible Materials Limited  
 Facility: G T S Flexible Materials Limited Form Number: Air1 / 02/09/2021

**Reporting of emissions to air for the period from 14/11/2024 to 14/11/2024**

Emission Point	Substance / Parameter	Emission		Result <sup>[1]</sup>	Test Method <sup>[2]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
		Limit Value	Reference Period				
Emission point from MCP	Carbon monoxide	No limit set	Periodic (average over one hour)	12.82 mg/m <sup>3</sup>	MCERTS BS EN 15058	14/11/24 11:10 - 12:10	2%
	Oxides of nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	100 mg/Nm <sup>3</sup> <sup>[5]</sup>	Periodic (average over one hour)	98.69 mg/m <sup>3</sup>	MCERTS BS EN 14792	14/11/24, 11:10 - 12:10	2%

Notes:


[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[5] At reference conditions of a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases at a standardised O<sub>2</sub> content of 6 % for solid fuels, 15 % for engines and gas turbines and 3 % for all other MCPs

Signe  .....  
 (Authorised to sign as representative of Operator)

Date..... 02/12/24