



Business Management System

# Annual permit report

Installation	Docksway
Permit reference	LP3135SB
Reporting period	2024
Permit Operator	Novera Energy

Author: [REDACTED]

Date: 15 January 2025 (v2)

Authorised to sign as representative of the Operator

<b>Fugitive Emissions Review (4.1.4)</b>		<b>Reporting period:</b>	<b>2024</b>
<b>Installation Name:</b>		<b>Docksway Landfill gas utilisation plant</b>	<b>Permit reference LP3135SB</b>
<b>Substances Released/Potentially</b>	<b>Description of event and any contamination/decontamination of the site which has occurred</b>		
Landfill gas	Details of any notifiable events have been submitted to NRW in accordance with our notification procedure		
Spillages	No significant spillages, contamination or decontamination to report for this installation		

Raw Materials (& Water) Assessment Table (S4.2 / 2.4)							
Site: Docksway		Reporting period: 2024		Permit Reference: LP3135SB			

Raw Materials	Application	Current Measures to Ensure Efficiency and Waste Minimisation	Annual Quantity Used	Fate of Material	Environmental Impact Potential	Reason Alternatives are Not Practicable	Details of Process Modifications which Could Result in Savings
Landfill gas	Fuel for engines to produce electricity	Kilowatt generation from volumes processed is maximised through effective operation, maintenance and servicing of plant	Variable depending on site conditions	Combustion	Potentially flammable, explosive, toxic, asphyxiant, ecotoxic, corrosive and odorous, greenhouse gas	N/A - Combustion of landfill gas essential for environmental control	N/A - environmental benefits to be gained from conversion of methane to CO2
Lubricating oils	To ensure efficiency of utilisation plant is maintained in accordance with manufacturer's instructions	Efficient use of lubricating oil is maximised through oil analysis to identify requirement for oil changes	Oil used is continually under review as part of the budgeting process	Reprocessing	Ecotoxic and odorous	Specification determined by engine manufacturer to ensure maximum performance and efficiency	Oil used is specialised for landfill gas fuel as recommended by the OEM. Oil change intervals are based on oil analysis therefore maximising efficiency and minimising use
Water	Coolant for engine block and domestic water supply	Cooling water is recirculated around the engines to maximise efficiency and minimise consumption	No water supply on site.	Treatment	Inert	N/A - Inert therefore best practicable environmental option	Re-use of water for coolant purposes ensures volumes used are as low as reasonably practicable. Cleaning practices assessed and minimal volumes used, cleaning practices are infrequent.
	Hygiene purposes	handwashing and (where available) toilet facilities		where installed toilet waste is removed from site and treated as sewerage	Inert	n/a	n/a
Glycol	Antifreeze for use in coolant water	Glycol is recirculated around the engines to maximise efficiency and minimise consumption	Glycol contained within enclosed-loop system is drained into a container for re-use. OEM* recommends change of glycol every 20,000 hours. Infnis policy is to change following natural depletion or contamination.	Reprocessing	Toxic, ecotoxic	Specification determined by engine manufacturer to ensure maximum performance and efficiency	Antifreeze mix is specific to engine type and pre-determined by the OEM*. Levels are topped-up following natural depletion or contamination
Battery Acid	In batteries used for engine start-up and to provide back-up power to ensure rapid restart following any loss of mains power supply	Battery use is essential minimised to the applications listed (see left)		Recycled	Corrosive	Portable electrical supply required for start-up	Minimal use of battery during start-up only therefore opportunity for savings is insignificant

\*OEM: Original Engine Manufacturer

## Waste Minimisation, Recovery and Disposal Assessment (2.6.2)

<b>Installation Name:</b> Docksway Gas Utilisation Plant	<b>Permit Reference:</b> LP3135SB	<b>Reporting period:</b> 2024
--	-----------------------------------	-------------------------------

Waste Stream	Application/Source	Current Measures to Ensure Efficiency and Waste Minimisation	Fate of Material	Reason Alternatives are Not Practicable	Details of Process Modifications which Could Result in Savings
Oil Filters (205ltr Drum)	Engine maintenance	Predetermined by manufacturers' recommendations to ensure efficiency	Reprocessing	Oil and filtration devices predetermined by manufacturers to ensure efficiency	Not applicable: oil filters changed at pre-determined life based on oil analysis and differential pressure
Oil Contaminated Rags & Absorbents (205ltr Drum)	Engine maintenance and housekeeping	Control measures in place to prevent spillage	Reprocessing	As above	No further modifications considered possible: Preventative maintenance and procedural practices minimise spillage and the requirement for oil absorbancy products
Waste Engine Oil (Bulk)	Engine maintenance	Efficient use of lubricating oil is maximised through oil analysis to identify requirement for oil changes	Reprocessing	As above	No further modifications considered possible: Oil used is specific to the landfill gas fuel in use and as recommended by the OEM*. Oil change intervals are based on oil analysis therefore maximising efficiency and minimising use
Batteries	Engine maintenance	Recharged	Recycled	Batteries essential for engine start-up and ensuring rapid restart	Batteries only replaced when they no longer hold a charge. Maintenance practices are in place to lengthen battery life
Fluorescent Tubes	Lighting	Replacement when faulty or damaged	Reprocessing	Alternatives not considered practicable due to warm-up time of energy saving bulbs	Tubes are only replaced when they have expired
General Waste	Packaging and general waste	Waste streams are seperated at site in line with current waste regulations and collected by contractors in line with current regulations	Disposal / recycling	Waste is disposed of in line with current regulations and recycled where this is practicable	Not applicable as a result of small quantities only being produced
Waste water/effluent	Welfare facilities	Facilities are maintained to ensure minimal water usage	Road tanker to treatment plant	Connection to mains sewer not practical - quantities produced are small.	Not applicable as a result of small quantities only being produced

\*Original Engine Manufacturer

### Annual Reporting of Other Performance Indicators (4.1.3)

<b>Installation:</b> Docksway Landfill Gas Utilisation Plant		<b>Permit Reference:</b> LP3135SB
<b>Parameter</b>	<b>2024</b>	<b>Units</b>
Flare operation hours	229	hrs
Gas engine downtime hours	334	hrs*
Gas engine operation hours	8450	hrs
Volume of landfill gas combusted	68,700	m3 (treated by flare)
	2,405,271	m3 (treated by engines)
	2,473,971	m3 (total treated by engines & flare)

#### Operator's Comments:

Gas volumes decreased in 2024. Please contact permit-compliance@infinis.com for any queries regarding the above.

### Reporting of Performance Indicators (Form Ref: PI1) Condition 2.7.1 (Table S3)

<b>Installation:</b> Docksway Landfill Gas Utilisation Plant	<b>Permit Reference:</b> LP3135SB
--	-----------------------------------

#### Annual Production/Treatment (MWh) (Form E1 - Table S3)

<b>Total production of energy</b>	3827
-----------------------------------	------

### Environmental Performance Indicators (Form PI1 S3)

Parameter	Annual Average 2024	Units	Trends in Environmental Performance	
			2022	2023
Total oxides of nitrogen (expressed as NO2) emission	1.3	Kg/MWh	1.6	1.6
Total carbon monoxide emission	3.6	Kg/MWh	4.1	3.8
Total engine downtime (downtime hrs/available operation time in hrs)	3.8	%	4.6	4.1

#### Condition 2.7.1 / 4.1.3 (Schedule 4)

Reporting period	Energy Imported (Primary Energy Usage) (MWh)	Parasitics (MWh)	Energy Exported (MWh)	Energy Used on Site (MWh)	Site Efficiency
<b>2024</b>	6	267	3560	273	34.3

\*site efficiency has been calculated as follows: ((Engine efficiency (%) x (gas to generation/total gas) x (power export / (power generation + imported power))).

<b>Installation:</b>	Docksway Landfill Gas Utilisation Plant	<b>Permit Reference:</b>	LP3135SB
----------------------	---	--------------------------	----------

<b>Accident Management Plan Review</b>	<b>2024</b>
<b>Date of next review</b>	
Reviewed monthly following a review of notifiable events	

(Permit condition 2.8.1)

<b>Operator's comments:</b>
No accidents occurred during this period which would require amendment to the Accident Management Plan for this installation.

<b>Installation:</b> Docksway Landfill Gas Utilisation Plant	<b>Permit Reference:</b> LP3135SB
<b>Emissions to Air Reporting (4.1.2.1)</b> 2024	
<b>Annual Report Submission Date</b>	29-May-24
<b>Submitted to</b>	Luke Barton & Liz Parr

Emission reports required by the permit (condition 4.1.2 / 4.1.3) were submitted to the relevant officer in 2024. The results indicated compliance with the levels noted in the permit.