

APPENDIX 14: WATER MASS BALANCE

	CURRENT m ³ /d		FUTURE m ³ /d	
	IN	OUT	IN	OUT
Jupiter	3172	2518	0	0
Neptune	985	680	985	680
Vesta	0	0	985	680
Boilerhouse	125	0	125	0
Jp service pump	50	50	0	0
Sprinkler purge	13	13	13	13
Filter backwash	110	110	64	64
Circulator overflows	222	222	100	100
Losses	258	258	30	30
Townswater	198	142	110	110
TOTAL	5133	3993	2412	1677