

Permit Number: BB3599CW

Operator: Vantage Data Centers UK Limited

Facility: **Newport Data Centre**


Form Number: **Performance 1 / 07/12/2022**

Reporting of other performance indicators for the year **2024**

<i>Parameter</i>	<i>Units</i>
Total diesel used	64 tonnes
Total other fuel used - HVO	3 tonnes
Generator operation for maintenance/testing: Total hours for the site	355 hours 11 minutes
Generator operation for maintenance/testing: Per generator <ul style="list-style-type: none"> • Total hours • Total number of runs • Number of minutes per run 	See spreadsheet attached (note 1) for information on individual generators, including: <ul style="list-style-type: none"> • Hours • Number of runs • Minutes per run
Generator operating during emergency scenario: <ul style="list-style-type: none"> • Total duration of emergency runs/events • Total number of emergency runs/events • Per run, number of engines and thermal capacity deployed 	There were no emergency scenarios at CWL11/12 in the reporting period.

Operator's comments :

1. For total hours per generator, number of runs per generator and number of minutes per run, see file "CWL1112 Annual Generator Hours 2024_FINAL"

Signed  Date...30/01/25.....
 (Authorised to sign as representative of Vantage Data Centres UK Limited)