

Permit Number: EPR/VP3736EF
Operator: The BOC Group Limited
Facility: Newport Steam Reforming Plant
Reporting: 4.2.2(a)

01/01/24 – 31/12/24

Reviewing the performance monitoring data for the installation for the given reporting period, the results are:

- Within the reporting limits for all parameters.

NOx emissions have remained in control at 72 mg/m³ which is well within the limit value of 140mg/m³.

██████████, Environment & Sustainability Manager

28/01/25