

# Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

## Part A

Permit Number	
Name of operator	
Location of Facility	
Time and date of the detection	

### **(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution**

#### **To be notified within 24 hours of detection**

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

### **(b) Notification requirements for the breach of a limit**

#### **To be notified within 24 hours of detection unless otherwise specified below**

Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

## Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

## Part C

Permit Number	<b>EPR/LP3030XA</b>
Name of operator	<b>Viridor Waste Management Limited</b>
Location of installation	<b>Cardiff Energy Recovery Facility, Trident Park, Cardiff.</b>

Time at which abnormal operation commenced	04_11_2019 at 02:30H
Time at which abnormal operation ceased	04_11_2019 at 02:59H
Duration of this incidence of abnormal operation	30 minutes
Cumulative abnormal operation duration in current year (at end of present incidence)	Total 2019 = Line 1 = 68 minutes  04/05/2019 38 minutes 04/11/2019 30 minutes  (allowed 60 hours per line per year)
Reasons for abnormal operation  ➤ Failure of the abatement plant.	The delivery pipe at the exit of the venturi become blocked with a build-up of solid urea.
How did the abnormal operation end? (e.g. plant repaired, reaching maximum permitted duration, initiation of shutdown, etc.)	Viridor employees cleared the pipe to return the flow rate of urea to normal. Going forward the pipe will be split at regular time intervals to ensure that that the opportunity of recurrence is reduced.  All other emissions remained under ELV.
Where the abnormal operation was caused by the failure of the particulate, CO or TOC CEM, attach a copy of the alternate monitoring data which was used to demonstrate compliance with the abnormal operation emission limit values.	Not applicable.

Where abatement plant has failed, give the half-hourly average emissions for pollutants of relevance during the abnormal operation in the rows below

Pollutant	1st ½ hour	2nd ½ hour	3rd ½ hour	4th ½ hour	5th ½ hour	6th ½ hour	7th ½ hour	8th ½ hour
NOx ½ hourly average  ELV = 400mg/m3	02:30H to 02:59H  402.09 mg/m3							
<b>Name*</b>	Gwyn Jones							
<b>Post</b>	Environment, Health and Safety Manager							
<b>Signature</b>	<i>G. Jones</i>							
<b>Date</b>	04_11_2019							

\* authorised to sign on behalf of **Viridor Waste Management Limited**