

Reporting of Emission to Groundwater for the period from 1st July 2024 to 31st December 2024.

Operator : RWE Generation UK plc

Form: Water1

Location: Aberthaw Quarry Ash Disposal Site

Permit/Variation Number: BP3339BH

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SW12	Aluminium, Dissolved		<3.5 µg/l		28/08/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		1.8 µg/l				
	Boron, Dissolved		1650 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		413 mg/l				
	Chromium, Dissolved		3.4 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		51 mg/l				
	Manganese, Dissolved		2.0 µg/l				
	Molybdenum, Dissolved		3370 µg/l				
	Nickel, Dissolved		5.1 µg/l				
	Selenium Dissolved		39.0 µg/l				
	Vanadium, Dissolved		4.1 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		71 mg/l				
	Electrical Conductivity at 20C		4070 mS/cm				
	Potassium, Dissolved		63 mg/l				
	Sodium, Dissolved		528 mg/l				
	Sulphate, Dissolved		1020 mg/l				
	Total Oxidised Nitrogen		15.0 mg/l				
	Chloride		834 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen		<0.41 mg/l					
Total Organic Carbon		6.0 mg/l					
Nitrate		14.3 mg/l					
pH		8.0 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SW12	Aluminium, Dissolved		3.7 µg/l		03/12/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		1.4 µg/l				
	Boron, Dissolved		991 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		255 mg/l				
	Chromium, Dissolved		4.4 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		34 mg/l				
	Manganese, Dissolved		0.6 µg/l				
	Molybdenum, Dissolved		1690 µg/l				
	Nickel, Dissolved		3.1 µg/l				
	Selenium Dissolved		18.3 µg/l				
	Vanadium, Dissolved		3.3 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		136 mg/l				
	Electrical Conductivity at 20C		2530 mS/cm				
	Potassium, Dissolved		39 mg/l				
	Sodium, Dissolved		269 mg/l				
	Sulphate, Dissolved		557 mg/l				
	Total Oxidised Nitrogen		10.5 mg/l				
	Chloride		402 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen		1.3 mg/l					
Total Organic Carbon		2.4 mg/l					
Nitrate		10.1 mg/l					
pH		7.8 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		6.3 µg/l		01/08/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<130 µg/l				
	Arsenic Dissolved	50	3.9 µg/l				
	Boron, Dissolved	2000	2370 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		545 mg/l				
	Chromium, Dissolved	50	15.0 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		55 mg/l				
	Manganese, Dissolved		61.6 µg/l				
	Molybdenum, Dissolved		4930 µg/l				
	Nickel, Dissolved		<100 µg/l				
	Selenium Dissolved		68.6 µg/l				
	Vanadium, Dissolved	60	12.5 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO ₃		132 mg/l				
	Electrical Conductivity at 20C		5460 mS/cm				
	Potassium, Dissolved		88 mg/l				
	Sodium, Dissolved		722 mg/l				
	Sulphate, Dissolved	400	1390 mg/l				
	Total Oxidised Nitrogen		33.7 mg/l				
	Chloride		1300 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen	0.6	10.9 mg/l					
Total Organic Carbon		2.9 mg/l					
Nitrate		29.9 mg/l					
pH	<9	7.5 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		11 µg/l		28/08/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<130 µg/l				
	Arsenic Dissolved	50	3.6 µg/l				
	Boron, Dissolved	2000	2250 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		588 mg/l				
	Chromium, Dissolved	50	13.8 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		54 mg/l				
	Manganese, Dissolved		70.9 µg/l				
	Molybdenum, Dissolved		5440 µg/l				
	Nickel, Dissolved		<1000 µg/l				
	Selenium Dissolved		70.6 µg/l				
	Vanadium, Dissolved	60	11.9 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO ₃		113 mg/l				
	Electrical Conductivity at 20C		5780 mS/cm				
	Potassium, Dissolved		89 mg/l				
	Sodium, Dissolved		806 mg/l				
	Sulphate, Dissolved	400	1350 mg/l				
	Total Oxidised Nitrogen		36.6 mg/l				
	Chloride		1270 mg/l				
Fluoride		0.2 mg/l					
Ammoniacal Nitrogen	0.6	8.8 mg/l					
Total Organic Carbon		3.6 mg/l					
Nitrate		30.3 mg/l					
pH	<9	7.7 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		11.5 µg/l		01/10/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	3.3 µg/l				
	Boron, Dissolved	2000	1880 µg/l				
	Cadmium, Dissolved	5	0.4 µg/l				
	Calcium, Dissolved		461 mg/l				
	Chromium, Dissolved	50	9.7 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		46 mg/l				
	Manganese, Dissolved		40.3 µg/l				
	Molybdenum, Dissolved		4110 µg/l				
	Nickel, Dissolved		8.2 µg/l				
	Selenium Dissolved		48.2 µg/l				
	Vanadium, Dissolved	60	10.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO ₃		142 mg/l				
	Electrical Conductivity at 20C		4170 mS/cm				
	Potassium, Dissolved		71 mg/l				
	Sodium, Dissolved		714 mg/l				
	Sulphate, Dissolved	400	1040 mg/l				
	Total Oxidised Nitrogen		25.8 mg/l				
	Chloride		974 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen	0.6	6.9 mg/l					
Total Organic Carbon		1.9 mg/l					
Nitrate		22.5 mg/l					
pH	<9	7.9 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		12.0 µg/l		04/11/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	2.5 µg/l				
	Boron, Dissolved	2000	1490 µg/l				
	Cadmium, Dissolved	5	<0.2 µg/l				
	Calcium, Dissolved		306 mg/l				
	Chromium, Dissolved	50	7.3 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		33 mg/l				
	Manganese, Dissolved		23.6 µg/l				
	Molybdenum, Dissolved		2360 µg/l				
	Nickel, Dissolved		6.7 µg/l				
	Selenium Dissolved		26.3 µg/l				
	Vanadium, Dissolved	60	7.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		205 mg/l				
	Electrical Conductivity at 20C		2880 mS/cm				
	Potassium, Dissolved		48 mg/l				
	Sodium, Dissolved		354 mg/l				
	Sulphate, Dissolved	400	646 mg/l				
	Total Oxidised Nitrogen		21.0 mg/l				
	Chloride		530 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen	0.6	4.6 mg/l					
Total Organic Carbon		1.5 mg/l					
Nitrate		19.1 mg/l					
pH	<9	7.8 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		11 µg/l		03/12/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	2.2 µg/l				
	Boron, Dissolved	2000	1180 µg/l				
	Cadmium, Dissolved	5	0.0 µg/l				
	Calcium, Dissolved		270 mg/l				
	Chromium, Dissolved	50	6.3 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		30 mg/l				
	Manganese, Dissolved		27.9 µg/l				
	Molybdenum, Dissolved		1960 µg/l				
	Nickel, Dissolved		5.3 µg/l				
	Selenium Dissolved		25.8 µg/l				
	Vanadium, Dissolved	60	6.1 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO ₃		213 mg/l				
	Electrical Conductivity at 20C		2700 mS/cm				
	Potassium, Dissolved		40 mg/l				
	Sodium, Dissolved		294 mg/l				
	Sulphate, Dissolved	400	532 mg/l				
	Total Oxidised Nitrogen		20.4 mg/l				
	Chloride		447 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen	0.6	4.1 mg/l					
Total Organic Carbon		1.4 mg/l					
Nitrate		19.2 mg/l					
pH	<9	7.8 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
Settlement Ponds	Aluminium, Dissolved		12 µg/l		02/01/2025	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved	50	2.7 µg/l				
	Boron, Dissolved	2000	1370 µg/l				
	Cadmium, Dissolved	5	<0.02 µg/l				
	Calcium, Dissolved		320 mg/l				
	Chromium, Dissolved	50	9.6 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		35 mg/l				
	Manganese, Dissolved		27.1 µg/l				
	Molybdenum, Dissolved		1990 µg/l				
	Nickel, Dissolved		6.7 µg/l				
	Selenium Dissolved		31.8 µg/l				
	Vanadium, Dissolved	60	8.3 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO ₃		194 mg/l				
	Electrical Conductivity at 20C		2910 mS/cm				
	Potassium, Dissolved		43 mg/l				
	Sodium, Dissolved		334 mg/l				
	Sulphate, Dissolved	400	651 mg/l				
	Total Oxidised Nitrogen		27.2 mg/l				
	Chloride		513 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen	0.6	2.5 mg/l					
Total Organic Carbon		0.9 mg/l					
Nitrate		25.8 mg/l					
pH	<9	7.8 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		42 µg/l		01/08/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<130 µg/l				
	Arsenic Dissolved		4.2 µg/l				
	Boron, Dissolved		2470 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		539 mg/l				
	Chromium, Dissolved		17.9 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		50 mg/l				
	Manganese, Dissolved		73.1 µg/l				
	Molybdenum, Dissolved		5160 µg/l				
	Nickel, Dissolved		<100 µg/l				
	Selenium Dissolved		73.5 µg/l				
	Vanadium, Dissolved		12.9 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		158 mg/l				
	Electrical Conductivity at 20C		5250 mS/cm				
	Potassium, Dissolved		84 mg/l				
	Sodium, Dissolved		664 mg/l				
	Sulphate, Dissolved		1320 mg/l				
	Total Oxidised Nitrogen		35.4 mg/l				
	Chloride		1100 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen		18.2 mg/l					
Total Organic Carbon		1.9 mg/l					
Nitrate		33.9 mg/l					
pH		7.2 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		34 µg/l		28/08/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		307.0 µg/l				
	Arsenic Dissolved		4.4 µg/l				
	Boron, Dissolved		2320 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		611 mg/l				
	Chromium, Dissolved		16.9 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		52 mg/l				
	Manganese, Dissolved		86.2 µg/l				
	Molybdenum, Dissolved		4850 µg/l				
	Nickel, Dissolved		<100 µg/l				
	Selenium Dissolved		72.9 µg/l				
	Vanadium, Dissolved		13.0 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		156 mg/l				
	Electrical Conductivity at 20C		5650 mS/cm				
	Potassium, Dissolved		88 mg/l				
	Sodium, Dissolved		743 mg/l				
	Sulphate, Dissolved		1360 mg/l				
	Total Oxidised Nitrogen		36.9 mg/l				
	Chloride		1200 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen		17.8 mg/l					
Total Organic Carbon		1.3 mg/l					
Nitrate		35.7 mg/l					
pH		7.1 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		17.3 µg/l		01/10/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		1.6 µg/l				
	Boron, Dissolved		1560 µg/l				
	Cadmium, Dissolved		0.3 µg/l				
	Calcium, Dissolved		417 mg/l				
	Chromium, Dissolved		5.6 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		43 mg/l				
	Manganese, Dissolved		67.4 µg/l				
	Molybdenum, Dissolved		3110 µg/l				
	Nickel, Dissolved		10.0 µg/l				
	Selenium Dissolved		38.3 µg/l				
	Vanadium, Dissolved		4.7 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		209 mg/l				
	Electrical Conductivity at 20C		4200 mS/cm				
	Potassium, Dissolved		64 mg/l				
	Sodium, Dissolved		726 mg/l				
	Sulphate, Dissolved		959 mg/l				
	Total Oxidised Nitrogen		19.9 mg/l				
	Chloride		1090 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen		9.9 mg/l					
Total Organic Carbon		1.5 mg/l					
Nitrate		19.5 mg/l					
pH		7.5 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		24 µg/l		04/11/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		2.7 µg/l				
	Boron, Dissolved		1390 µg/l				
	Cadmium, Dissolved		0.2 µg/l				
	Calcium, Dissolved		322 mg/l				
	Chromium, Dissolved		9.7 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		32 mg/l				
	Manganese, Dissolved		39.8 µg/l				
	Molybdenum, Dissolved		2450 µg/l				
	Nickel, Dissolved		6.4 µg/l				
	Selenium Dissolved		30.9 µg/l				
	Vanadium, Dissolved		7.4 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		220 mg/l				
	Electrical Conductivity at 20C		3030 mS/cm				
	Potassium, Dissolved		46 mg/l				
	Sodium, Dissolved		342 mg/l				
	Sulphate, Dissolved		664 mg/l				
	Total Oxidised Nitrogen		22.3 mg/l				
	Chloride		556 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen		7.4 mg/l					
Total Organic Carbon		1.3 mg/l					
Nitrate		21.5 mg/l					
pH		7.3 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		14 µg/l		03/12/2024	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		1.6 µg/l				
	Boron, Dissolved		985 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		257 mg/l				
	Chromium, Dissolved		5.6 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		26 mg/l				
	Manganese, Dissolved		36.0 µg/l				
	Molybdenum, Dissolved		1780 µg/l				
	Nickel, Dissolved		6.4 µg/l				
	Selenium Dissolved		24.0 µg/l				
	Vanadium, Dissolved		4.5 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO3		232 mg/l				
	Electrical Conductivity at 20C		2620 mS/cm				
	Potassium, Dissolved		36 mg/l				
	Sodium, Dissolved		270 mg/l				
	Sulphate, Dissolved		464 mg/l				
	Total Oxidised Nitrogen		21.2 mg/l				
	Chloride		426 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen		4.8 mg/l					
Total Organic Carbon		1.4 mg/l					
Nitrate		20.8 mg/l					
pH		7.1 pH Units					

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
DP2	Aluminium, Dissolved		26 µg/l		02/01/2025	Sampling RWE / Testing ALS	
	Antimony, Dissolved		<1.3 µg/l				
	Arsenic Dissolved		2.7 µg/l				
	Boron, Dissolved		1390 µg/l				
	Cadmium, Dissolved		<0.02 µg/l				
	Calcium, Dissolved		345 mg/l				
	Chromium, Dissolved		10.2 µg/l				
	Copper, Dissolved		<4 µg/l				
	Iron, Dissolved		<20 µg/l				
	Magnesium, Dissolved		36 mg/l				
	Manganese, Dissolved		41.0 µg/l				
	Molybdenum, Dissolved		2100 µg/l				
	Nickel, Dissolved		7.2 µg/l				
	Selenium Dissolved		35.2 µg/l				
	Vanadium, Dissolved		7.3 µg/l				
	Mercury, Dissolved		<0.01 µg/l				
	Total Alkalinity as CaCO ₃		207 mg/l				
	Electrical Conductivity at 20C		3040 mS/cm				
	Potassium, Dissolved		41 mg/l				
	Sodium, Dissolved		342 mg/l				
	Sulphate, Dissolved		692 mg/l				
	Total Oxidised Nitrogen		26.4 mg/l				
	Chloride		545 mg/l				
	Fluoride		0.2 mg/l				
Ammoniacal Nitrogen		4.4 mg/l					
Total Organic Carbon		<0.7 mg/l					
Nitrate		25.7 mg/l					
pH		7.0 pH Units					

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.


[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

Emission point	Substance/ Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
----------------	-------------------------	-------------------------	-----------------------	-------------------------------	---	--	-------------------------------

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[6] The emission limit values for all substances is expressed as a maximum individual value, unless otherwise stated.

Signed  Date 05/02/2025
 (authorised to sign as representative of the Operator)