Form CP63-3 revB

MERTHYR (SOUTH WALES) LTD

WATER SPOT CHECK SAMPLING

Site Name:		**Cwmbargoed Disposal Point (D.P.)**		
Permit No:	**AE2013403**	**Month:**	**Oct 2024**	**Date of inspection 02.10.24**

Reporting of emissions to water (other than to sewer)

Monitoring Point	Suspended Solids Consent limits	pH Consent limits	Date of Sample	Discharge Status	pH result	Sus Solids result	Iron as Fe (mg/l)	Weather Conditions
Point 'C' (Final Effluent)	100 mg/l	5-9	02- 10- 24	Discharging (Low Flow)	7.7	8	0.02	Dry
Point 'C1' (Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	N/A	Dry

Notes:

Suspended Solids (Point 'C') reduced to 100mg/l between 1st January 2024 – 31st December 2024.
Suspended Solids (Point 'C') reduced to 80mg/l between 1st January 2025 – 31st December 2025.
Suspended Solids (Point 'C') reduced to 50mg/l between 1st January 2026 – 31st December 2026.
Suspended Solids (Point 'C1' – Storm Overflow) remains at 500mg/l

Name	[redacted]	Position:	D.P. Restoration Manager	Date:		27/02/2025