Form CP63-3 revB

**MERTHYR (SOUTH WALES) LTD**

# WATER SPOT CHECK SAMPLING

| | | | | |
|---|---|---|---|---|
| **Site Name:** | | **Cwmbargoed Disposal Point (D.P.)** | | |
| **Permit No:** | **AE2013403** | **Month:** | **August 2024** | **Date of inspection 30.08.24** |

**Reporting of emissions to water (other than to sewer)**

| Monitoring Point | Suspended Solids Consent limits | pH Consent limits | Date of Sample | Discharge Status | pH result | Sus Solids result | Iron as Fe (mg/l) | Weather Conditions |
|---|---|---|---|---|---|---|---|---|
| Point 'C' (Final Effluent) | 100 mg/l | 5-9 | 30- 08- 24 | Not Discharging | 7.5 | <5 | 0.01 | Dry |
| Point 'C1' (Storm) | N/A | N/A | N/A | Not Discharging | N/A | N/A | N/A | Dry |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

**Notes:**

**Suspended Solids (Point 'C') reduced to 100mg/l between 1st January 2024 – 31st December 2024.**
**Suspended Solids (Point 'C') reduced to 80mg/l between 1st January 2025 – 31st December 2025.**
**Suspended Solids (Point 'C') reduced to 50mg/l between 1st January 2026 – 31st December 2026.**
**Suspended Solids (Point 'C1' – Storm Overflow) remains at 500mg/l**

| | | | | | | |
|---|---|---|---|---|---|---|
| Name | [redacted] | Position: | D.P. Restoration Manager | Date: | | 27/02/2025 |