

## Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

### Part A

Permit Number	<b>EPR/EP3738NG</b>
Name of operator	<b>WEPA UK Ltd</b>
Location of Facility	<b>Bridgend Paper Mill</b>
Time and date of the detection	<b>15:00hrs Friday 7<sup>th</sup> March 2025</b>

<b>(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment</b>	
<b>To be notified Immediately</b>	
Date and time of the event	<b>15:00hrs Friday 7<sup>th</sup> March 2025</b>
Reference or description of the location of the event	<b>A partial discharge occurred in the Combined Heat and Power (CHP) plant within the insulation system of the high-voltage circuit. Therefore the CHP has been shut for safety reasons pending investigation. An emergency (temporary) steam boiler is to be sourced and installed to ensure steam supply and paper production continues during the investigation.</b>
Description of where any release into the environment took place	<b>N/A</b>
Substances(s) potentially released	<b>N/A</b>
Best estimate of the quantity or rate of release of substances	<b>N/A</b>
Measures taken, or intended to be taken, to stop any emission	<b>N/A</b>
Description of the failure or accident.	<b>An investigation has been initiated to understand the cause of the partial discharge. No injuries or environmental breaches have occurred.</b>

### Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify,	

limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	<b>Notifications in the preceding 24 months:</b> None

<b>Name*</b>	[REDACTED]
<b>Post</b>	Energy & Environment Manager
<b>Signature</b>	[REDACTED]
<b>Date</b>	06/03/2025

\* authorised to sign on behalf of WEPA UK Ltd