

Permit Number: PAN-005576/V003

Operator: Dragon Fruit Holdings Limited

Facility: Parc Busnes Edwards Biomass Boiler


Form Number: Air1 / 29/09/2021

Reporting of emissions to air for the period from 14/04/22 to 27/11/24 Boilers 2&3

Emission Point	Substance / Parameter	Emission		Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value*	Reference Period				
A2	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	500 mg/m ³	Periodic	258	BS EN 14792	27 th November 2024 12:05 - 13:05	2.3%
A2	Dust	50 mg/m ³	Periodic	45.8	BS EN 13284-1	27 th November 2024 12:04 - 13:06	4.4%
A2	Carbon monoxide	No limit set	Periodic	339	BS EN 15058	27 th November 2024 12:05 - 13:05	0.5%
A3	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	500 mg/m ³	Periodic	261	BS EN 14792	27 th November 2024 09:50 - 10:50	6.5%
A3	Dust	50 mg/m ³	Periodic	25.1	BS EN 13284-1	27 th November 2024 09:46 - 10:50	2.3%
A3	Carbon monoxide	No limit set	Periodic	77	BS EN 15058	27 th November 2024 09:50 - 10:50	2.2%

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

* Monitoring requirements are defined at a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases at a standardised O₂ content of 6 % for solid fuels, 15 % for engines and gas turbines and 3 % all other MCPs

Signed 
 (Authorised to sign as representative of Operator)

Date 16/01/25.