

# Schedule 6 - Notification

This page outlines the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

## Part A

Permit Number	<b>EPR-MP3330WP</b>
Name of operator	<b>Resources Management U.K. Ltd.</b>
Location of Facility	<b>Withyhedge Landfill Site Bowling Farm Rudbaxton Haverfordwest Pembrokeshire SA62 4DB</b>
Time and date of the detection	<b>01/11/2025</b>

<b>(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution</b>	
<b>To be notified within 24 hours of detection</b>	
Date and Time of the event	<b>01/11/2025</b>
Reference or description of the location of the event	<b>Gas Compound</b>
Description of where any release into the environment took place	<b>No release into the environment occurred. Odour monitoring response initiated.</b>
Substances(s) potentially released	<b>Not applicable, no release has occurred. Odour monitoring response initiated.</b>
Best estimate of the quantity or rate of release of substances	<b>Not applicable, no release has occurred. Odour monitoring response initiated.</b>
Measures taken, or intended to be taken, to stop any emission	<b>Odour monitoring response initiated.</b>
Description of the failure or accident.	<b>Electrical surge from grid due to storm conditions (Lightning), caused power outage across the compound. This tripped the main booster which in turn shut down the generators. Downtime at compound were at approximately 12.30am. Technician attended site at 4.00am, compound operational by 4.45am.</b>

<b>(b) Notification requirements for the breach of a limit</b>	
<b>To be notified within 24 hours of detection unless otherwise specified below</b>	
Emission point reference/ source	N/A
Parameter(s)	N/A
Limit	N/A
Measured value and uncertainty	N/A
Date and time of monitoring	N/A
Measures taken, or intended to be taken, to stop the emission	N/A

<b>Time periods for notification following detection of a breach of a limit</b>	
<b>Parameter</b>	<b>Notification period</b>
All to be notified within 24 hours.	-

<b>(c) Notification requirements for the detection of any significant adverse environmental effect</b>	
<b>To be notified within 24 hours of detection</b>	
Description of where the effect on the environment was detected	N/A
Substances(s) detected	N/A
Concentrations of substances detected	N/A
Date of monitoring/sampling	N/A

**Part B to be supplied as soon as practicable.**

Any more accurate information on the matters for notification under Part A.	Gas compound fully operational.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Emergency procedures are in place for such event and will be reviewed.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Scheduled odour monitoring regime to be undertaken.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	Not applicable

<b>Name*</b>	Mr Gavin R Powell
<b>Post</b>	Group Technical Manager
<b>Signature</b>	<i>GRPowell</i>
<b>Date</b>	02/11/2025

\* authorised to sign on behalf of Resources Management U.K. Limited.