

RELEASES TO AIR 2022

RETURN OF DISCONTINUOUS MONITORING RESULTS

Operator: Uskmouth Power Company

Location: Newport

Permit/Variation Number: LP3131SW/V002

Form:

Version:

IED PM1

V.11 Mar 2016

Year: 2022	LCP				
Six months to -					
Measurement approach	NO _x	SO ₂	CO	Hg	Dust
Time	0	0	0	0	0
Date	0	0	0	0	0
Measurement 1 (mg/m ³) ^(b)	0	0	0	0	0
Measurement 2 (mg/m ³) ^(b)	0	0	0	0	0
Measurement 3 (mg/m ³) ^(b)	0	0	0	0	0
Alternative approach ^(c)					
Method ^(d)	0	0	0	0	0
Calculation (mg/m ³)	0	0	0	0	0
Operational data ^(a)					
Load (%MCR)	0	0	0	0	0
Fuel 1 name (%)	0	0	0	0	0
Fuel 2 name (%)	0	0	0	0	0
Fuel 3 name (%)	0	0	0	0	0
Daily Emission Limit Value					
(mg/m ³)					

NOTES:

(a) Operational data for the test period (measurement approach) or the six month period to date (Alternative approach)

(b) Reference conditions for mg/m³ are 15% O₂ CCGT, 6% O₂ solid fuels, 3% O₂ for oil and gas, dry, 0°C, 101.325 kPa

(c) Alternative approach to discontinuous monitoring by agreement with the Competent Authority

(d) Use abbreviation: NF for agreed NO_x factor, FS for fuel sulphur content, CS for agreed CO factor, DF for agreed dust factor

Signed on behalf of the Operator by:

.....

Date of return:

.....24/01/2023.....