

Permit Number: EPR/EP3830GH

Operator: Liberty Steel UK Ltd

Facility: Liberty Steel Newport

Form Number:

Water1 / 15/08/2016

Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2025 to 31/03/2025

Emission Point	Emission		Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
	Substance / Parameter	Limit Value					
W1	Total suspended solids	20 mg/l	Spot Sample	11	BS EN 872:1996 or other ISO, BS or SCA blue book method as approved by Natural Resources Wales	09.02.2025 12:00	5.65
W1	Total Hydrocarbons	5 mg/l	Spot Sample	0.011	SCA blue book 77 ISBN 0117517283 2002 or other ISO, BS or SCA blue book method as approved by Natural Resources Wales	09.02.2025 12:00	0.016
W1	pH	6-10	Spot Sample	11.0	BS 6068-2.50:1995 (ISO 10523:1994)	08.01.2025 12:00	9.39
W1	Lead	0.1 mg/l	Spot Sample	0.012	BS 6068-2.60:1998, BS EN ISO 11885 1998	08.01.2025 12:00	0.004
W1	Arsenic	0.1 mg/l	Spot Sample	0.003	BS 6068-2.60:1998, BS EN ISO 11885 1998	09.02.2025 12:00	0.002
W1	Cadmium	0.006 mg/l	Spot Sample	0.0001	BS 6068-2.60:1998, BS EN ISO 11885 1998	09.02.2025 12:00	0.0001

