

NOT YET COMMISSIONED

Date of form 13/10/14

NOT YET COMMISSIONED

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: [March 2025](#)

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator:

Date: 30/04/2025



Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [March 2025](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.267	0.267	30/01/2025
Suspended Solids mg/l	50	5	6	30/01/2025
Mineral oil and hydrocarbons mg/l	5	1.69	0.267	05/02/2025
Suspended Solids mg/l	50	18	8	05/02/2025
Mineral oil and hydrocarbons mg/l	5	1.91	0.46	06/03/2025
Suspended Solids mg/l	50	8	8	06/03/2025

Signed on behalf of the Operator:

Date: 30/04/2025



Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [March 2025](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.00	6.40	6.92	7.10
Total suspended solids mg/l	600	18.00	44.31	65.60	68.00
Total chemical oxygen demand (COD) mg/l	3600	96.00	238.15	330.20	362.00
Free or emulsified grease or oil mg/l	100	3.68	9.90	21.35	21.90
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.50	1.72	7.86	8.10
Ammoniacal nitrogen as N mg/l	30	3.71	8.26	12.18	12.90
Daily flow m ³ /day	800	131.17	535.18	738.72	769.73
Maximum flow m ³ /h	34	5.47	22.30	30.78	32.07

Signed on behalf of the Operator:

Date: 30/04/2025

