

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/EP3738NG
Name of operator	WEPA UK Ltd
Location of Facility	Bridgend Paper Mill
Time and date of the detection	15:00hrs Friday 7th March 2025

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment

To be notified Immediately	
Date and time of the event	15:00hrs Friday 7th March 2025
Reference or description of the location of the event	A partial discharge occurred in the Combined Heat and Power (CHP) plant within the insulation system of the high-voltage circuit. Therefore the CHP has been shut for safety reasons pending investigation. An emergency (temporary) steam boiler is to be sourced and installed to ensure steam supply and paper production continues during the investigation.
Description of where any release into the environment took place	N/A
Substances(s) potentially released	N/A
Best estimate of the quantity or rate of release of substances	N/A
Measures taken, or intended to be taken, to stop any emission	N/A
Description of the failure or accident.	An investigation has been initiated to understand the cause of the partial discharge. No injuries or environmental breaches have occurred.

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	N/A
Measures taken, or intended to be taken, to prevent a recurrence of the incident	CHP boiler system shut down and decommissioned, new boiler systems were brought online and commissioned on the 25th April. The

	temporary boilers were taken off the same day. Following of the closure of the CHP the electrical discharge is no longer a safety concern as the system has been decommissioned.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	The temporary boiler system has been removed. The new boiler system exhaust is delivered to the atmosphere via a new stack as per permit variation and deemed to be compliant. Permit variation submitted on 03/09/2024.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	Notifications in the preceding 24 months: None

Name*	
Post	Energy & Environment Manager
Signature	
Date	01/05/2025

* authorised to sign on behalf of WEPA UK Ltd