

Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	BX3376IG
Name of Operator	Continental Teves,
Location of Installation	Ebbw Vale
Location of the emission	Effluent Treatment Plant
Time and date of the emission	17.04.2025

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Ni – 3.2 mg/l	Effluent discharge - water	Approximately 2,000 litres	10.00
Consent level is 2 mg/l max			

This is Welsh Water Sample report of 17.04.25	Continental Result of sample was 1.56 mg/l. Analysis of duplicate sample retained by Continental on 10.05.25 was 1.60 mg/l
---	---

Part B

Any more accurate information on the matters for notification under Part A.	See description below
Measures taken, or intended to be taken, to prevent a recurrence of the incident	1. All out-of-date material to be disposed of via waste contractor. 2. Alternative chemicals to be sought for treating of Ni-complexes 3. Undertake performance checks on analytical instrumentation
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	Water is discharged to foul sewer for further treatment. It is unlikely at the values found that any pollution of the environment is caused
The dates of any unauthorised emissions from the installation in the preceding 24 months.	None

Name*	
Post	Head of Plating, Environmental Management and Training
Signature	
Date	02.05.2025

* authorised to sign on behalf of Continental Teves UK Limited