


|                                                                                  |                                   |
|----------------------------------------------------------------------------------|-----------------------------------|
| <b>NRW Permit Number:</b> DB3494ZX (PAN-012754)                                  | <b>Operator:</b> Photonics UK LTD |
| <b>Facility:</b> CHP at Photonics UK LTD, 1 Technology Drive, Bridgend, CF31 3LU | <b>Form Number:</b> Air1          |

**Reporting of emissions to air for the period from 02/08/2024 to 02/08/2024**

| Emission Point                                                        | Substance / Parameter                            | Emission Limit Value | Reference Period    | Result | Test Method                  | Sample Date and Times |
|-----------------------------------------------------------------------|--------------------------------------------------|----------------------|---------------------|--------|------------------------------|-----------------------|
| Inside the CHP container, upstream of the Exhaust gas heat exchanger. | Oxides of Nitrogen (NO and NO2 expressed as NO2) | 95 mg/m <sup>3</sup> | In line with TGN M5 | 93.46  | RASI 800 Analyser-S/N 017232 | 02/08/2024 at 12:20   |
|                                                                       | Carbon monoxide                                  | No limit set         | In line with TGN M5 | 181.73 | RASI 800 Analyser-S/N 017232 | 02/08/2024 at 12:20   |

Signed ...  .....

Date.....25-06-2025.....

(Authorised to sign as representative of Operator)