

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	TP3639BH
Name of operator	CELSA Manufacturing (UK) Ltd
Location of Facility	Seawall Road, Tremorfa, Cardiff CF24 5TH
Time and date of the detection	25/06/2025 08:00

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	23/06/2025
Reference or description of the location of the event	A1 Meltshop Furnace Stack – Particulate CEMS unit
Description of where any release into the environment took place	Point source emission to atmosphere
Substances(s) potentially released	Particulates
Best estimate of the quantity or rate of release of substances	Unknown
Measures taken, or intended to be taken, to stop any emission /	An investigation into the cause behind the monitor not sending the data for this day has been initiated.
Description of the failure or accident.	Equipment failure – CEMS unit failed to send emissions data on the date of the 23 rd June. Schedule 3 of the permit states a requirement for

	continuous daily average sampling for particulates from the A1 reference emissions point.
--	---

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and Time of Monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	

Date of monitoring/sampling	
-----------------------------	--

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	To install routine software updates for the CEMS operating system, the system has to restart. This can prevent the automatic report being distributed to all relevant personnel if the report is scheduled to be sent during this update window. However, there is no loss of data as the system still records in the background.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The scheduled time of when the CEMS report is automatically distributed has been changed so that it does not coincide with the routine system software update windows.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	N/A: Data for 23/06/25 shows that there was no breach of emissions.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	15/07/2023, 04/08/2023, 24/10/2023 13/11/2023, 20/11/2023, 25/11/2023, 29/11/2023, 13/12/2023, 21/12/2023, 01/01/2024, 17/01/2024, 31/05/2024, 01/06/2024, 12/07/2024, 21/09/2024, 24/09/2024, 07/10/2024, 12/10/2024, 17/06/2025.

Name*	
Post	Environmental Advisor
Signature	
Date	27/06/2025

* authorised to sign on behalf of CELSA Manufacturing UK Limited