

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorized emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number / Variation Notice Number	BR8212IK / (EPR/BR8212IK/V004)
Name of operator	Knauf Insulation
Location of Installation	Cwmbran
Time and date of the detection	11/09/2020 approx 21:00

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	11 th September 2020 approx 21:00
Reference or description of the location of the event	Knauf Insulation, Cwmbran
Description of where any release into the environment took place	Water used to extinguish a fire within the sprinkler pump house. All contaminated water contained within the sites interceptor system
Substance(s) potentially released	Water used to extinguish fire
Best estimate of the quantity or rate of release of substance	Unknown
Measures taken, or intended to be taken, to stop any emission	Sites water interceptor and containment systems
Description of the failure or accident	Investigation ongoing

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	N/A
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Substance(s) detected	N/A
Concentrations of substances detected	N/A
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	Sprinkler pump fire within the sprinkler pump house. Faulty starter motor identified as source of fire
Measures taken, or intended to be taken, to prevent a recurrence of the incident	New fire sprinkler pump and starter motor installed.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	None required as firewater contained within the sites interceptor system. Fuel tanks relocated outside of building in new bunded area.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	22/11/2018 – High SO2 emission

Name*	[REDACTED]
Post	HS&E Manager
Signature	[REDACTED]
Date	27/05/2021

* authorised to sign on behalf of Knauf Insulation Limited