



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905IP **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 06/06/2022

PART A														
Name of the prescribed substance or other substance which might cause harm Elevated suspended solids in effluent														
Time, date and location of the release Elevated suspended solids levels were recorded on 02nd June 2022 at the W1 effluent release point.														
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place Levels in excess of the 100mg/l limit were recorded, at 364 mg/l for average (360 mg/l for original result and 368 mg/l for the retest). Previous and subsequent results have been below the limit of 100mg/l, and the weekly average was below the permitted limit at 87.14 mg/l. <table><tbody><tr><td>29/05/2022</td><td>56</td></tr><tr><td>30/05/2022</td><td>36</td></tr><tr><td>31/05/2022</td><td>28</td></tr><tr><td>01/06/2022</td><td>52</td></tr><tr><td>02/06/2022</td><td>364</td></tr><tr><td>03/06/2022</td><td>16</td></tr><tr><td>04/06/2022</td><td>62</td></tr></tbody></table>	29/05/2022	56	30/05/2022	36	31/05/2022	28	01/06/2022	52	02/06/2022	364	03/06/2022	16	04/06/2022	62
29/05/2022	56													
30/05/2022	36													
31/05/2022	28													
01/06/2022	52													
02/06/2022	364													
03/06/2022	16													
04/06/2022	62													
Additional information Further investigation information to follow in Part B.														
Measures taken, or intended to be taken to stop the release Investigating drain outlets and activities that could influence this release.														

Name: [REDACTED] **Position:** Environmental Engineer

Signature: [REDACTED]