



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905IP **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 28/10/2022

PART A																	
Name of the prescribed substance or other substance which might cause harm	Elevated total suspended solids (TSS) in effluent.																
Time, date and location of the release	Elevated TSS levels were recorded on 25th October 2022 at the W1 effluent release point.																
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place	Levels in excess of the 100 mg/l limit were recorded, at 195 mg/l for average (242 mg/l for original result and 148 mg/l for the retest). Previous results in the past week have been below the limit of 100 mg/l. <table><tbody><tr><td>19/10/2022</td><td>2</td></tr><tr><td>20/10/2022</td><td>2</td></tr><tr><td>21/10/2022</td><td>16</td></tr><tr><td>22/10/2022</td><td>26</td></tr><tr><td>23/10/2022</td><td>30</td></tr><tr><td>24/10/2022</td><td>34</td></tr><tr><td>25/10/2022</td><td>195</td></tr><tr><td>26/10/2022</td><td>26</td></tr></tbody></table>	19/10/2022	2	20/10/2022	2	21/10/2022	16	22/10/2022	26	23/10/2022	30	24/10/2022	34	25/10/2022	195	26/10/2022	26
19/10/2022	2																
20/10/2022	2																
21/10/2022	16																
22/10/2022	26																
23/10/2022	30																
24/10/2022	34																
25/10/2022	195																
26/10/2022	26																
Additional information	Further investigation information to follow in Part B.																
Measures taken, or intended to be taken to stop the release	Investigating drain outlets and activities that could influence this release.																

Name: [REDACTED] **Position:** Environmental Engineer

Signature: [REDACTED]