



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905IP **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 02/02/2022

PART A																			
Name of the prescribed substance or other substance which might cause harm	Elevated suspended solids in effluent																		
Time, date and location of the release	Elevated suspended solids levels were recorded on 29th January 2022 at the W1 effluent release point.																		
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place	Levels in excess of the 100mg/l limit were recorded, at 246mg/l for original result and 240 mg/l for the retest. Subsequent results have been within permitted levels, and weekly average is below the limit at 83.71 mg/l. <table><tbody><tr><td>23/01/2022</td><td>86</td></tr><tr><td>24/01/2022</td><td>86</td></tr><tr><td>25/01/2022</td><td>28</td></tr><tr><td>26/01/2022</td><td>26</td></tr><tr><td>27/01/2022</td><td>98</td></tr><tr><td>28/01/2022</td><td>16</td></tr><tr><td>29/01/2022</td><td>246</td></tr><tr><td>30/01/2022</td><td>24</td></tr><tr><td>31/01/2022</td><td>22</td></tr></tbody></table>	23/01/2022	86	24/01/2022	86	25/01/2022	28	26/01/2022	26	27/01/2022	98	28/01/2022	16	29/01/2022	246	30/01/2022	24	31/01/2022	22
23/01/2022	86																		
24/01/2022	86																		
25/01/2022	28																		
26/01/2022	26																		
27/01/2022	98																		
28/01/2022	16																		
29/01/2022	246																		
30/01/2022	24																		
31/01/2022	22																		
Additional information	Further investigation information to follow in Part B.																		
Measures taken, or intended to be taken to stop the release	Investigating drain outlets and activities that could influence this release.																		

Name: [REDACTED] **Position:** Environmental Engineer

Signature: [REDACTED]