



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905IP **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 26/05/2022

PART A										
Name of the prescribed substance or other substance which might cause harm Elevated suspended solids in effluent										
Time, date and location of the release Elevated suspended solids levels were recorded on 24th May 2022 at the W1 effluent release point.										
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place Levels in excess of the 100mg/l limit were recorded, at 222mg/l for average (218mg/l for original result and 226 mg/l for the retest). Previous and subsequent results have been below the limit of 100mg/l.<table><tbody><tr><td>21/05/2022</td><td>42</td></tr><tr><td>22/05/2022</td><td>26</td></tr><tr><td>23/05/2022</td><td>54</td></tr><tr><td>24/05/2022</td><td>222</td></tr><tr><td>25/05/2022</td><td>20</td></tr></tbody></table>	21/05/2022	42	22/05/2022	26	23/05/2022	54	24/05/2022	222	25/05/2022	20
21/05/2022	42									
22/05/2022	26									
23/05/2022	54									
24/05/2022	222									
25/05/2022	20									
Additional information Further investigation information to follow in Part B.										
Measures taken, or intended to be taken to stop the release Investigating drain outlets and activities that could influence this release.										

Name: [REDACTED] **Position:** Environmental Engineer

Signature: [REDACTED]