



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905IP **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 10/08/2022

PART A																			
Name of the prescribed substance or other substance which might cause harm	Elevated oil in effluent																		
Time, date and location of the release	Elevated oil levels were recorded on 8th August 2022 at the W1 effluent release point.																		
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place	Levels in excess of the 5 mg/l limit were recorded, at 8.05 mg/l for average (8.3 mg/l for original result and 7.8 mg/l for the retest). Previous results in the past week have been below the limit of 5 mg/l. <table><tbody><tr><td>31/07/2022</td><td>0.7</td></tr><tr><td>01/08/2022</td><td>5</td></tr><tr><td>02/08/2022</td><td>1.2</td></tr><tr><td>03/08/2022</td><td>3.7</td></tr><tr><td>04/08/2022</td><td>2.6</td></tr><tr><td>05/08/2022</td><td>1.6</td></tr><tr><td>06/08/2022</td><td>2.7</td></tr><tr><td>07/08/2022</td><td>3.4</td></tr><tr><td>08/08/2022</td><td>8.05</td></tr></tbody></table>	31/07/2022	0.7	01/08/2022	5	02/08/2022	1.2	03/08/2022	3.7	04/08/2022	2.6	05/08/2022	1.6	06/08/2022	2.7	07/08/2022	3.4	08/08/2022	8.05
31/07/2022	0.7																		
01/08/2022	5																		
02/08/2022	1.2																		
03/08/2022	3.7																		
04/08/2022	2.6																		
05/08/2022	1.6																		
06/08/2022	2.7																		
07/08/2022	3.4																		
08/08/2022	8.05																		
Additional information	Further investigation information to follow in Part B.																		
Measures taken, or intended to be taken to stop the release	Investigating drain outlets and activities that could influence this release.																		

Name: [REDACTED] **Position:** Environmental Engineer

Signature: [REDACTED]