



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905IP **Location:** Llanwern works
Newport

Date Submitted: 18/12/2023 South Wales
NP19 4QZ

PART A
<ul style="list-style-type: none">Name of the prescribed substance or other substance which might cause harm Elevated Suspended Solids (SS) in effluent.
<ul style="list-style-type: none">Time, date and location of the release This part A S5N_23_78A issued is for elevated suspended solids recorded at W1 effluent consent point on the 10th December 2023.
<ul style="list-style-type: none">Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place Levels in excess of the 100 mg/l limit were recorded on the 10th December, with a measured value of 209 mg/l, reportable 173 mg/l with uncertainty of measurement of 36 mg/l subtracted. The weekly average for week 50 for suspended solids at W1 29.86 mg/l, after uncertainty of 36 mg/l was applied, which is below the 100 mg/l limit.
<ul style="list-style-type: none">Additional information Further investigation information to follow in Part B.
<ul style="list-style-type: none">Measures taken, or intended to be taken to stop the release Investigating drain outlets and activities that could influence this release.

Name: [REDACTED] **Position:** Environment Officer

Signature [REDACTED]