



Schedule 1

Notification of Unauthorised Release

Operator: Tata Steel Strip Products UK

Authorisation: BS3905IP **Location:** Llanwern works
Newport
South Wales
NP19 4QZ

Date Submitted: 05/11/2019

PART A
Name of the prescribed substance or other substance which might cause harm Suspended solids in effluent
Time, date and location of the release 1st November 2019, W1 consent point
Best estimate of the quantity of the substance released, or the rate of release and the time during which the release took place Concentration levels in excess of the 100mg/l limit were recorded with a peak of 178mg/l
Additional information Further investigation information to follow in Part B. Local area has experienced heavy rainfall, elevating water levels in main east west ditches and lagoon 14. Potential contribution from neighbouring land to the west of Llanwern plant is also being investigated.
Measures taken, or intended to be taken to stop the release Investigation of drain outlets that could influence this release. Suspended solid results for 2nd and 3rd November have been within consent levels.

Name: Hayley Jeremiah

Position: Fire & Environment Manager Llanwern

Signature: