

NOT YET COMMISSIONED

Date of form 13/10/14

Date of form 13/10/14

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [June 2025](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	1.91	0.927	10/04/2025
Suspended Solids mg/l	50	8	8	10/04/2025
Mineral oil and hydrocarbons mg/l	5	0.54	2.62	01/05/2025
Suspended Solids mg/l	50	8	31	01/05/2025
Mineral oil and hydrocarbons mg/l	5	0.307	0.38	05/06/2025
Suspended Solids mg/l	50	3	8	05/06/2025

Signed on behalf of the Operator:

Date: 21/07/2025



Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [June 2025](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.10	7.18	9.42	10.2
Total suspended solids mg/l	600	11.00	41.77	76.00	79.00
Total chemical oxygen demand (COD) mg/l	3600	156.00	246.77	308.60	323.00
Free or emulsified grease or oil mg/l	100	2.27	7.41	15.00	15.90
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.50	1.09	3.06	5.70
Ammoniacal nitrogen as N mg/l	30	1.13	7.60	14.70	15.30
Daily flow m ³ /day	800	90.98	466.86	684.94	706.53
Maximum flow m ³ /h	34	3.79	19.45	28.54	29.44

Signed on behalf of the Operator:

Date: 21/07/2025

